

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated: 4-18-14
 Proposed Facility: SFD Design Flow (.1949): 600 Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L-34%	0-5	LOAM	CLAY SAND					
		5-40	CLAY	CLAY SAND	30" SR				.3
2	L-4%	0-8	LOAM	CLAY SAND					
		8-40	CLAY	CLAY SAND	36" SR				.35
3	L-24%	0-10	SL LOAM	CLAY SAND					
		10-40	SANDY	CLAY SAND	30-32" SR				.3

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)			Site Classification (.1948):
System Type(s)	<u>250</u>	<u>250</u>	Evaluated By: <u>[Signature]</u>
Site LTAR	<u>.3</u>	<u>.3</u>	Others Present: