

HTE# 14-5-34942

Harnett County Department of Public Health

23500

PERMIT # 28098

Operation Permit

[X] New Installation [X] Septic Tank [X] Nitrification Line [] Repair [] Expansion

PROPERTY LOCATION: 51415 PANTS CAVIAR RD

Name: (owner) Comfort Homes Inc SUBDIVISION STATION LOT # 25

System Installer: Russell Phillips Registration #

Basement with plumbing: [] Garage [X] Number of Bedrooms 3


Type of Water Supply: [] Community [X] Public [] Well Distance from well _____ feet

System Type: 25% Reduction Type III B-2000 Types V and VI Systems expire in 5 years.

(In accordance with Table V a) Owner must contact Health Department 6 months prior to expiration for permit renewal.

Quick Check

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.



PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Rule .1961.
- II. Monitoring: As required by Rule .1961.
- III. Maintenance: As required by Rule .1961. Other: _____
Subsurface system operator required? Yes [] No []
If yes, see attached sheet for additional operation conditions, maintenance and reporting.

IV. Operation: _____
V. Other: _____

[] D-Box [] Pump [] Alarm [] H2O Line [] PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: [] Conventional [X] Other 25% Reduction Syst Septic Tank: 1000 gallons Pump Tank: 1000 gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 80 feet width of ditches 3 feet depth of ditches 28 inches

French Drain Required: _____ Linear feet

Authorized State Agent James E. M... Date 2-12-15