

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: **3600m** Design Flow (.1949): **360 gpd** Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941		.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
			.1941 Structure/ Texture	.1941 Consistence Mineralogy					
1	LS 5-7	0-12"	GS	VFL NS/UP					
		12-16"	SBX L	FL S/SR					
		16"	PM						US
2		0-20"	GS	VFL NS/UP					
		20-40"	SBX ALL	FL S/SR					PS .5
3		0-30"	GS	VFL NS/UP					
		30-48"	SBX ⁺ SCL ⁺	FL BS/UP					PS .5
4		0-12"	GS	VFL NS/UP					S/S

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)			Site Classification (.1948): PS
System Type(s)	0.1 MP	25% G	Evaluated By: ST
Site LTAR	.5	S	Others Present: