

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: *STANCO*
 Address: Date Evaluated: *198-15*
 Proposed Facility: *SFD* Design Flow (.1949): *360* Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	<i>L-578</i>	0-12	<i>LOAM</i>	<i>FR GR N20P</i>	<i>ROCKS</i>				
		12-24	<i>SCL</i>	<i>2 1/2" FR 1 W 55SP</i>					
		24-42	<i>SC-CLAY</i>	<i>FR 1 1/2" S.P</i>	<i>30" WATER 27"</i>				<i>135</i>
2	<i>L-7-93</i>	0-15	<i>LOAM</i>	<i>FR GR N20P</i>	<i>ROCKS</i>				
		15-26	<i>SCL</i>	<i>2 1/2" FR 1 W 55SP</i>					
		26-42	<i>SC-CLAY</i>	<i>FR 1 1/2" S.P</i>	<i>WATER 36"</i>				<i>.4</i>
3	<i>L-</i>	0-12	<i>LOAM</i>	<i>FR GR N20P</i>	<i>ROCKS</i>				
		12-30	<i>SCL</i>	<i>2 1/2" FR 1 W 55SP</i>					
		30-48	<i>SC-CLAY</i>	<i>FR 1 1/2" S.P</i>	<i>WATER 46" 48"</i>				<i>.4</i>

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)			Site Classification (.1948): <i>125</i>
System Type(s)	<i>2502</i>	<i>252</i>	Evaluated By: <i>[Signature]</i>
Site LTAR	<i>.35</i>	<i>.35</i>	Others Present: