


**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: *[Signature]* Date Evaluated: *2-24-15*
 Address: Design Flow (.1949): *360* Property Size:
 Proposed Facility: *S&D* Property Recorded:
 Location of Site: Public Individual Well Spring Other
 Water Supply: Auger Boring Pit Cut
 Evaluation Method: Sewage Industrial Process Mixed
 Type of Wastewater:

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L-5%	0-30	SL	fr G.R.N.S.P					
		30-40	SCL-	fr G.R.N.S.P	40" P _n	40"		P _n	.4
2	L-4.5%	0-24	SL	fr G.R.N.S.P					
		24-40	SCL	fr G.R.N.S.P	36" P _n	36"		P _n	.4
3	L-3.4%	0-24	SL	fr G.R.N.S.P					
		24-40	SCL	fr G.R.N.S.P	38-40" ^{WET} P _n			P _n	.4
4	L	0-26	SL	fr G.R.N.S.P					
		26-40	SCL	fr G.R.N.S.P	36" ^{WET} P _n	P _n		P _n	.4

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)	/	/	Site Classification (.1948):
System Type(s)	252	252-PPBS	Evaluated By: <i>[Signature]</i>
Site LTAR	.4	4	Others Present: <i>[Signature]</i>



PLOT PLAN FOR COMFORT HOMES BLACK RIVER TOWNSHIP HARNETT COUNTY NORTH CAROLINA

Curve	Radius	Length	Chord	Chord Bear.
C1	1825.00'	100.01'	100.00'	N 35°23'51" W

NOTE: THIS PROPERTY IS SUBJECT TO EASEMENTS AND RESTRICTIONS OF RECORD.
PRELIMINARY PLAT- NOT FOR RECORDATION, CONVEYANCES, OR SALES.

NOTE: BEING LOT 18 OF STETSON SUBDIVISION, RECORDED IN MAP NUMBER 2008 PGS. 193-196 AND RE-RECORDED IN MAP NUMBER 2008 PGS. 199-200.

NOTE: AREA COMPUTED BY COORDINATE METHOD.

NOTE: NO NCGS CONTROL MONUMENT WITHIN 2000'.

NOTE: LOTS TO BE SERVED BY HARNETT COUNTY WATER AND INDIVIDUAL SEPTIC SYSTEMS.

IMPERVIOUS SURFACE COVERAGE
2037 SQ.FT. - HOUSE & GARAGE
128 SQ.FT. - WALK & STEPS
763 SQ.FT. - DRIVEWAY
2928 TOTAL SQ.FT. - PROPOSED COVERAGE
9754 SQ.FT. - ALLOWABLE COVERAGE
6826 SQ.FT. - AVAILABLE COVERAGE

"I, Danny D. Williams, certify that this map was drawn under my supervision that the boundaries not surveyed are indicated as drawn from information in Map Number 2008 PGS. 193-200 that the ratio of precision or positional accuracy is 1:1000, and that this map meets the requirements of the Standards and Practice for Land Surveying in North Carolina."


This 14TH day of JANUARY, 2015.

Seal


 DANNY O. WILLIAMS
 Professional Land Surveyor

NOTE: NOT AN ACTUAL FIELD COPY. INFORMATION TAKEN FROM MAP NUMBER 2008 PGS 193-195.

WILLIAMS - PEARCE and ASSOC.,
PROFESSIONAL LAND SURVEYORS, P.A.
 1000 N. ARENDELL AVE.
 P.O. BOX 892, ZEBULON, N.C. 27597
 PHONE: 919-269-9605 LIC. # C-0243



MARIE COBLE
 DB 745 PC 3889



DRAWN BY: DOW & BGW
 CHECKED BY: DOW
 DATE: 01-14-2015
 SCALE: 1" = 50'
 JOB: STETSON CF
 FB:

