

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: Gibson
 Address: Date Evaluated: 2-6-91
 Proposed Facility: SFD Design Flow (.1949): 3200 Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1,2	<u>C-2.3%</u>	<u>0-16</u>	<u>SL</u>	<u>fine-grained</u>					
		<u>16-44</u>	<u>SC-clay</u>	<u>fine / silty S.P.</u>	<u>40" 7.5% 3-1</u>				<u>14-3</u>
3	<u>C-2.3%</u>	<u>0-15</u>	<u>SL</u>	<u>fine-grained</u>					
		<u>15-42</u>	<u>SC-clay</u>	<u>fine / silty S.P.</u>	<u>36" 7.5% 3-1</u>				<u>13</u>

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <u>13</u> Evaluated By: <u>[Signature]</u> Others Present:
Available Space (.1945)			
System Type(s)	<u>262</u>	<u>PPBS</u>	
Site LTAR	<u>13</u>	<u>3</u>	

COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	NS-NON-STICKY SS-SLIGHTLY STICKY S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6		
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT	0.6 - 0.3		
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1		
FP-FLOOD PLAN		C-CLAY SC-SANDY CLAY			

STRUCTURE

- SG-SINGLE GRAIN
- M-MASSIVE
- CR-CRUMB
- GR-GRANULAR
- SBK-SUBANGULAR BLOCKY
- ABK-ANGULAR BLOCKY
- PL-PLATY
- PR-PRISMATIC

MINERALOGY

- SLIGHTLY EXPANSIVE
- EXPANSIVE

Show profile locations and other site features (dimensions, references or benchmark, and North)

A large grid for site profile and feature recording. The grid consists of 20 columns and 20 rows. A vertical red line is drawn through the grid, approximately one-third of the way from the left edge. The grid is intended for recording profile locations and other site features, including dimensions, references, benchmarks, and North orientation.