

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                      Date Evaluated:  
 Proposed Facility: 3 BRM                      Design Flow (.1949): 360 gpd                      Property Size:  
 Location of Site:                      Property Recorded:  
 Water Supply:                       Public  Individual  Well                       Spring                       Other  
 Evaluation Method:  Auger Boring                       Pit                       Cut  
 Type of Wastewater:  Sewage                       Industrial Process                       Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	<u>LS 15-20</u>	<u>0-8</u>	<u>GL</u>	<u>VFLNS/MP</u>					
		<u>2-42</u>	<u>SBKC</u>	<u>FRI s/p</u>					<u>PS .25</u>
2		<u>0-6</u>	<u>GL</u>	<u>VFLNS/MP</u>					
		<u>6-40</u>	<u>SBKC</u>	<u>F1 s/p</u>					<u>PS .25</u>
3		<u>0-10</u>	<u>GL</u>	<u>VFLNS/MP</u>					
		<u>10-40</u>	<u>SBKC</u>	<u>F1 s/p</u>					<u>PS .25</u>
4		<u>0-12</u>	<u>GL</u>	<u>VFLNS/MP</u>					
		<u>12-42</u>	<u>SBKC</u>	<u>F1 s/p</u>					<u>PS .25</u>

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Site Classification (.1948): <u>PS</u>
System Type(s)	<u>25% EB</u>	<u>PUMP 25%</u>	Evaluated By: <u>ST</u>
Site LTAR	<u>.25</u>	<u>.25</u>	Others Present: <u>BM</u>

30x20 e 8"