

ADDRESS : 220 CURRAGH CV SUBDIV: MAGNOLIA CREST 29LOTS
 CONTRACTOR : STRONG BUILT HOMES OF NC, INC. PHONE : (919) 662-2624
 OWNER : MARKET VIEW LANE LLC PHONE :
 PARCEL : 08-0655- - -0067- -18-
 APPL NUMBER: 15-50035494 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 02/10/2015 11:03 AM VBROWN ----
 CURRAGH COVE, MAGNOLIA CREST #17
 PREMISE # 28514639

STRUCTURE: 000 000 55X37 4BDR 2.5BATH SFD

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/02/15	BS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002641348 T/S: April 02, 2015 10:35 AM BSUTTON -----
B103 01	4/07/15	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002643112 T/S: 04/06/2015 01:54 PM LBENNETT ----- T/S: April 07, 2015 12:13 PM BSUTTON -----
B105 01	4/20/15	DT	R*OPEN FLOOR VRU #: 002647980 Morning inspection if possible. Thank You T/S: 04/20/2015 02:04 PM DETAYLOR -----
A814 01	5/18/15	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002659944 T/S: 05/18/2015 10:02 AM SBENNETT -----
R125 01	5/18/15	BS	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 002659951 T/S: 05/15/2015 09:51 AM DJOHNSON ----- THIS IS FOR A SHEATHING INSPECTION. CUSTOMER PAID THE EXTRA FEE FOR THIS. T/S: May 18, 2015 10:33 AM BSUTTON ----- Roof flashing must be under wrap. Window missing. Ok to start siding, dont cover wall to roof instersections.
R125 02	5/22/15	DT	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 002662781 T/S: 05/21/2015 01:58 PM LBENNETT ----- T/S: 05/22/2015 01:37 PM DETAYLOR -----
H824 01	6/02/15	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002667566 PER JAMES MANHART OPERATIONS PERMIT ON HOLD FOR INSPECTION OF PIPE UNDER DRIVEWAY. CALL HIM WHEN READY 893-7547. T/S: 06/02/2015 03:16 PM SSTEWARD ----- T/S: 06/02/2015 03:17 PM SSTEWARD -----
R425 01	6/04/15	BS	FOUR TRADE ROUGH IN VRU #: 002667525 T/S: June 04, 2015 10:11 AM BSUTTON ----- Per John Strong
R425 02	6/08/15	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002669745 T/S: June 08, 2015 11:34 AM BSUTTON ----- Add missing Jack studs at right rear as circled on plan. rear door should have 2x12 header as shown on plan. Add hangers at 12"OC floor joist above garage as shown on plan. Correct all above or provide engineering letter for approval of changes. Ok to insulate.
I129 01	6/10/15	BS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002670271

----- CONTINUED ONTO NEXT PAGE -----

ADDRESS : 220 CURRAGH CV SUBDIV: MAGNOLIA CREST 29LOTS
 CONTRACTOR : STRONG BUILT HOMES OF NC, INC. PHONE : (919) 662-2624
 OWNER : MARKET VIEW LANE LLC PHONE :
 PARCEL : 08-0655- - -0067- -18-
 APPL NUMBER: 15-50035494 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	6/11/15	AP	T/S: 06/08/2015 02:00 PM LBENNETT ----- T/S: 06/09/2015 07:54 AM DJOHNSON ----- T/S: 06/09/2015 07:54 AM DJOHNSON ----- T/S: June 11, 2015 08:04 AM BSUTTON -----
R425 03	6/10/15 6/11/15	BS AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002670297 T/S: 06/08/2015 02:00 PM LBENNETT ----- T/S: 06/09/2015 07:54 AM DJOHNSON ----- T/S: 06/09/2015 07:54 AM DJOHNSON ----- T/S: June 11, 2015 08:04 AM BSUTTON -----
R125 03	6/16/15 6/16/15	BS AP	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 002674315 T/S: 06/15/2015 01:40 PM LBENNETT ----- LATH INSPECTION T/S: June 16, 2015 12:39 PM BSUTTON -----
E209 01	7/30/15 7/30/15	BS AP	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002696565 T/S: July 30, 2015 02:01 PM BSUTTON -----
H824 02	7/31/15 7/31/15	JM AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002698140 T/S: 08/03/2015 12:22 PM SSTEWARD ----- T/S: 08/03/2015 12:22 PM SSTEWARD -----
R429 01	8/06/15 8/06/15	BS DA	FOUR TRADE FINAL VRU #: 002699551 T/S: August 06, 2015 10:26 AM BSUTTON ----- X brace rear deck. 2. Water heater T&P must exit crawl through indirect waste line. 3. Caulk lineset sleeves and cable/phone penetrations
R429 02	8/07/15 <u>8-7-15</u>	TI <u>APBS</u>	FOUR TRADE FINAL VRU #: 002700151

----- COMMENTS AND NOTES -----

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ Occupancy:

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Name: Strong Built Homes

Address: 220 Curragh Cv

Figuoy Vanna N.C 27526

Date: 8-7-15

Building Official: Brad Gutter

Permit Numbers

Building: 15-50035494

Electrical: " "

Insulation: " "

Plumbing: " "

Mechanical: " "

MFG Home: _____