

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: BRUNO
 Address: Date Evaluated: 3-13-16-11
 Proposed Facility: SPR Design Flow (.1949): 480 Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1,2,3	L-45%	0-30	SL	FL GARDEN P					
		30-48	SL	fm 1 ^W BKLS.P	46-48"				.4
3	L-45%	0-40	SL	FL GARDEN P					
		40-48	SL	fm 1 ^W BKLS.P	46-48"				.4
4	L-3%	0-20		FL GARDEN P					
		20-48		fm 1 ^W BKLS.P	-48"				.4
5,6	L-34%	0-20	SL	FL GARDEN P					
OUT.		22-48	SL	fm 1 ^W BKLS.P	36"+				.4

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)		?	Site Classification (.1948): PS
System Type(s)	25%	PPBS	Evaluated By: J.M.O.T
Site LTAR	.4	.4	Others Present: