Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant: Stamel
Address: Date Evaluated: 3-10-15
Proposed Facility: SFD Design Flow (.1949): 360 Property Size:
Location of Site: Property Recorded:
Water Supply: ☑ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☑ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L 2SE	0-18	SL	FRGRNPSP					
		18-44	SCL	Fmbsbs.P	38-40" 2.5Y 3/1				.4
2,3	L 3E	0-20	SL	FRGRNSP					
		20-48	SCL	Fmbsbs.P	42" 2.5Y 3/1				.4

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	2SE	2SE
Site LTAR	.4	.4

Other Factors (.1946):
Site Classification (.1948): PS
Evaluated By:
Others Present: