

PREPARED 7/23/15, 14:14:35
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

SUBDIV: OAKMONT PH1 SC3 52LOTS
PHONE : (919) 793-5237
PHONE :

ADDRESS : 67 ELGIN DR
CONTRACTOR : GML DEVELOPMENT INC
OWNER : OAKMONT DEV PTNRS LLC
PARCEL : 03-0507-01- -0046- -33-
APPL NUMBER: 15-50035778 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 03/25/2015 04:16 PM JBROCK
OAKMONT LOT 114

STRUCTURE: 000 000 59X41 4BDR MONO W/ GARAGE
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4000000.00
SEPTIC - EXISTING? : NEW TANK

PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------|-------------|---|
| A814 01 | 5/04/15 5/05/15 | SB AP | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002654531 67 ELGIN DR LILLINGTON 27546 T/S: 05/05/2015 08:28 AM SBENNETT |
| P309 01 | 5/04/15 5/04/15 | MR AP | R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002654523 T/S: 05/04/2015 12:30 PM MREARIC |
| B114 01 | 5/06/15 5/07/15 | MR AP | R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002655843 T/S: 05/07/2015 01:11 PM MREARIC |
| B104 01 | 6/08/15 6/08/15 | JB AP | R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002670362 T/S: 06/08/2015 02:55 PM JBROCK |
| R425 01 | 6/09/15 6/09/15 | MR DA | FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002670370 T/S: 06/09/2015 01:22 PM MREARIC T/S: 06/09/2015 01:23 PM MREARIC wire bath fans // ac duct in bath is loose // mark dryer length // fill holes under tubs // foam all air barriers // ok to insulate |
| I129 01 | 6/11/15 6/11/15 | MR AP | R*INSULATION INSPECTION TIME: 17:00 VRU #: 002671709 T/S: 06/11/2015 02:53 PM MREARIC |
| R425 02 | 6/11/15 6/11/15 | MR AP | FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002671691 T/S: 06/11/2015 02:53 PM MREARIC |
| H824 01 | 6/16/15 6/16/15 | OT AP | ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002677698 T/S: 06/22/2015 08:58 AM SSTEWARD T/S: 06/22/2015 08:59 AM SSTEWARD |
| E209 01 | 7/14/15 7/14/15 | MR CA | R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002686897 T/S: 07/14/2015 01:59 PM MREARIC |
| E209 02 | 7/16/15 7/16/15 | MR AP | R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002688141 would like an afternoon inspection T/S: 07/15/2015 12:06 PM DJOHNSON T/S: 07/16/2015 01:37 PM MREARIC |
| R429 01 | 7/24/15 | TI | FOUR TRADE FINAL VRU #: 002693356 <u>lc</u> <u>AP-IVR</u> |

COMMENTS AND NOTES

