

HTE# 15-5-35798

Hamilton County Department of Public Health

28357

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: BIM BUILDERS LLC

PROPERTY LOCATION: 81705 OLD FAIRGROUND RD

NEW [x] REPAIR [] EXPANSION []

SUBDIVISION _____ LOT # _____

Type of Structure: SFJ

Site Improvements required prior to Construction Authorization Issuance:

Proposed Wastewater System Type: 25% REDUCTION

Projected Daily Flow: 480 GPD

Number of bedrooms: 4 Number of Occupants: 8 max

Basement [] Yes [x] No

Pump Required: [] Yes [] No [x] May be required based on final location and elevations of facilities

Type of Water Supply: [] Community [x] Public [] Well Distance from well _____ feet

Permit valid for: [x] Five years [] No expiration

Permit conditions: _____

Authorized State Agent: James E. Manshart

Date: 4-14-15

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: BIM BUILDERS LLC

PROPERTY LOCATION: 81705 OLD FAIRGROUND RD

Facility Type: SFJ [x] New [] Expansion [] Repair

SUBDIVISION _____ LOT # _____

Basement? [] Yes [x] No Basement Fixtures? [] Yes [x] No

Type of Wastewater System** 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 480 GPD

(See note below, if applicable []) Pump to 25% REDUCTION (Repair)

Installation Requirements/Conditions

Septic Tank Size 1200 gallons

Number of trenches 9 Exact length of each trench 80 feet

Trench Spacing: 9 Feet on Center

Pump Tank Size _____ gallons

Trenches shall be installed on contour at a

Soil Cover: 6 inches

Maximum Trench Depth of: 24 MAX inches

(Maximum soil cover shall not exceed

(Trench bottoms shall be level to +/-1/4" in all directions)

36" above the trench bottom)

Pump Requirements: _____ ft. TDH vs. _____ GPM

Aggregate Depth: 6 inches below pipe

2 inches above pipe

Conditions: _____

12 inches total

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Manshart

Date: 4-14-15

Construction Authorization Expiration Date: 4-14-20

HTE# 15-5-35798

Permit # 28357

Harnett County Department of Public Health Site Sketch

ISSUED TO: BIM BUIDARS PROPERTY LOCATOR: 521705 OLD FOREGROUND
SUBDIVISION _____ LOT # _____

Authorized State Agent: James E. Manhart Date: 4-14-15

