

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant: *moore*
 Address: Date Evaluated: *4-29-15*
 Proposed Facility: *SFD* Design Flow (.1949): *560* Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1.2	<i>L-35%</i>	0-14	<i>SL</i>	<i>FC GRND C</i>					
		14-32	<i>SC-1M</i>	<i>FM 180KSP</i>	<i>30" 7-1/2</i>				<i>.3</i>
3.4	<i>L-35%</i>	0-15	<i>SL</i>	<i>FC GRND C</i>					
		15-30	<i>SC-1M</i>	<i>FM 180KSP</i>	<i>30-32" 7-1/2</i>				<i>.3</i>

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: <i>[Signature]</i> Others Present:
Available Space (.1945)	<i>1</i>	<i>1</i>	
System Type(s)	<i>2</i>	<i>2</i>	
Site LTAR	<i>-3</i>	<i>.3</i>	