Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant: McCuff
Address: Date Evaluated: 4-27-15
Proposed Facility: SFD + Gar Design Flow (.1949): 360 Property Size:
Location of Site: Property Recorded:
Water Supply: ☑ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☑ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1,2,3	L-3%	0-10	SL-Loam	Fr Granular					
		10-36	SC-Clay	Fr Subangular Blocky	34" 7.5YR 3/3				.3

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	2 SR	2 SR
Site LTAR	.3	.3

Other Factors (.1946):
Site Classification (.1948): PS
Evaluated By:
Others Present: