

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: ARAGUATI  
 Address: Date Evaluated: 2-6-85  
 Proposed Facility: SFD Design Flow (.1949): 6-5-8-15 Property Size:  
 Location of Site: Property Recorded:  
 Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L-3%	0-18	SL	FR GAYNSP					
		18-42	SCL	FR 1/2 BK S.P.	38-40' <sup>water</sup> 5"				.3
2	L-3%	0-20	SL	FR GAYNSP					
		20-42	SCL	FR 1/2 BK S.P.	40-42' <sup>water</sup> 2"				.4 - .35
3.4	L-5%	0-18	SL	FR GAYNSP					
		18-40	SCL	FR 1/2 BK S.P.	36' <sup>water</sup> 2.5" 2"				.3

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: <u>[Signature]</u> Others Present:
Available Space (.1945)	/	/	
System Type(s)	75%	25%	
Site LTAR	.3	.3	