

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: *Buller*
 Address: Date Evaluated: *4/26/18*
 Proposed Facility: *SD* Design Flow (.1949): *5000 yd* Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	<i>L 5.02</i>	<i>0-21</i>	<i>SL low</i>	<i>fine sand</i>	<i>red</i>				
		<i>21-18</i>	<i>SL</i>	<i>fine sand sp</i>	<i>red 46" 5.1</i>				<i>.4</i>
2	<i>L 4.5</i>	<i>0-14</i>	<i>SL</i>	<i>fine sand</i>	<i>red</i>				
		<i>14-14</i>	<i>SC - clay</i>	<i>fine sand</i>	<i>41" 5.1</i>				<i>.3</i>
3	<i>L 4.5</i>	<i>0-15</i>	<i>SL</i>	<i>fine sand</i>	<i>red</i>				
		<i>15-36</i>	<i>SL</i>	<i>fine sand</i>	<i>34 5.1</i>				<i>.3</i>
4	<i>L 5.2</i>	<i>0-22</i>	<i>SL</i>	<i>fine sand</i>	<i>red</i>				
		<i>22-44</i>	<i>SL</i>	<i>fine sand</i>	<i>42" 5.1</i>				<i>.35</i>
5	<i>L 5.6</i>	<i>0-12</i>	<i>SL</i>	<i>fine sand</i>					
		<i>12-20</i>	<i>SC</i>	<i>fine sand</i>	<i>34 5.1</i>				<i>.3</i>
6	<i>L 5.9</i>	<i>0-12</i>	<i>SL</i>	<i>fine sand</i>					
		<i>12-28</i>	<i>SC</i>	<i>fine sand</i>	<i>42" 5.1</i>				<i>.3</i>
7	<i>L 4</i>	<i>0-12</i>	<i>SL</i>	<i>fine sand</i>					
		<i>12-42</i>	<i>SC</i>	<i>fine</i>	<i>37 5.1</i>				<i>.3</i>

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: <i>[Signature]</i> Others Present: <i>[Signature]</i>
Available Space (.1945)			
System Type(s)	<i>282</i>	<i>283</i>	
Site LTAR	<i>.3</i>	<i>.3</i>	