

October 25, 2021

Richard Ypina
55 Sedgefield Ln
Spring lake, NC 28390

Re: Status of Improvement Permit Application- CPSF15-50036445

To whom it may concern:

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to accurately mark property lines and irons that are set by surveyor need to be visible. (*\$25.00 fee incurred*)
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs brush, vegetation, and old barn and scrap removed from septic system area
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. **Other- Accurately stake off all buildings to be located on the lot**

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Mark Osborne REHS
Environmental Health Specialist
Harnett County Department of Public Health

MO/KH
Copy: Central Permitting