

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                      Date Evaluated: 7/17/15  
 Proposed Facility:              Design Flow (.1949):              Property Size:  
 Location of Site:              Property Recorded:  
 Water Supply:               Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
	1529	0-10	G/SL	VFWSNP					
		10-48	SAP/C	F-SSP					PS.4
		<del>48-57</del>							
		57-72	G/LS	VFWSNP					
		0-10	G/SL	VFWSNP					
		10-38	SAP/C	F-SSP					PS.4
		38-61	G/LS	VFWSNP					
		0-15	G/SL	VFWSNP					
		15-35	SAP/C	F-SSP					PS.4
		35-65	G/LS	VFWSNP					
		0-8	G/SL	VFWSNP					PS.4
		8-20	SAP/RC	F-SSP					
		20-48	G/LS	VFWSNP					

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: [Signature] Others Present:
Available Space (.1945)			
System Type(s)	258	258	
Site LTAR	11	11	