

HTE# REPAIR

# Harrison County Department of Public Health

29121

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: \_\_\_\_\_

ISSUED TO: \_\_\_\_\_ SUBDIVISION \_\_\_\_\_ LOT # \_\_\_\_\_

NEW  REPAIR  EXPANSION  Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: \_\_\_\_\_

Proposed Wastewater System Type: \_\_\_\_\_

Projected Daily Flow: \_\_\_\_\_ GPD

Number of bedrooms: \_\_\_\_\_ Number of Occupants: \_\_\_\_\_ max

Basement  Yes  No

Pump Required:  Yes  No  May be required based on final location and elevations of facilities

Type of Water Supply:  Community  Public  Well Distance from well \_\_\_\_\_ feet Permit valid for:  Five years

Permit conditions: \_\_\_\_\_  No expiration

Authorized State Agent: \_\_\_\_\_ Date: \_\_\_\_\_ SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

## Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: MCKEE HOMES PROPERTY LOCATION: \_\_\_\_\_

SUBDIVISION OAKMONT LOT # 53

Facility Type: EXISTING SFD  New  Expansion  Repair

Basement?  Yes  No Basement Fixtures?  Yes  No

Type of Wastewater System\*\* \_\_\_\_\_ (Initial) Wastewater Flow: 480 GPD

(See note below, if applicable ) Pump To 25% Reg. Sys. (Repair)

### Installation Requirements/Conditions

Septic Tank Size EXIST gallons Number of trenches 1

Pump Tank Size EXIST gallons Exact length of each trench 225 feet Trench Spacing: 9 Feet on Center

Trenches shall be installed on contour at a Maximum Trench Depth of: 18 inches (Maximum soil cover shall not exceed 36" above the trench bottom)

(Trench bottoms shall be level to +/-1/4" in all directions)

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM \_\_\_\_\_ inches below pipe

Aggregate Depth: \_\_\_\_\_ inches above pipe

Conditions: SEE SKETCH FOR GUIDANCE. DO NOT TIE NEW \_\_\_\_\_ inches total

LING INTO OLD LING, SET NEW D-BOX. INSTALL FENCE TO PREVENT FUTURE DAMAGE

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.**

**NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_


This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: \_\_\_\_\_ Date: 12/8/16

Construction Authorization Expiration Date: 12/6/21

# Southeastern Soil & Environmental Associates, Inc.

P.O. Box 9321  
 E2003400 Fayetteville, NC 28311 E2003500  
 Phone/Fax (910) 822-4540  
 Email mike@southeasternsoil.com



Proposed Septic (off site) Layout, Oakmont Subdivision  
 Lots 53 & 54, Countryside Drive, Harnett County, NC

US State Plane 1983  
 North Carolina 3200  
 NAD 1983 (Conus)



Scale 1:600

1" = 50'



Feet

OAKMONT-56.SSF

2/1/2016

GPS Pathfinder® Office

