

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: WILLIAM JEFFREY BYRD
PROPERTY LOCATION: HOLLIES PINES RD
SUBDIVISION: TURKEY TROT II LOT # 14
NEW [] REPAIR [] EXPANSION [x]
Type of Structure: 3 Bedroom Home
Proposed Wastewater System Type: CONVENTIONAL
Projected Daily Flow: 360 GPD
Number of bedrooms: 3 Number of Occupants: 6 max
Basement [] Yes [x] No
Pump Required: [] Yes [x] No
Type of Water Supply: [] Community [x] Public [] Well
Distance from well: 70 feet
Permit valid for: [x] Five years [] No expiration

Authorized State Agent: [Signature] RENT Date: 12/5/16 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: WILLIAM JEFFREY BYRD
PROPERTY LOCATION: HOLLIES PINES RD
SUBDIVISION: TURKEY TROT II LOT # 14
Facility Type: 3 Bedroom Home [] New [x] Expansion [] Repair
Basement? [] Yes [x] No Basement Fixtures? [] Yes [x] No
Type of Wastewater System: CONVENTIONAL (Initial) Wastewater Flow: 360 GPD
(See note below, if applicable [])
CONVENTIONAL (Repair)

Installation Requirements/Conditions
Septic Tank Size: EXISTING gallons
Pump Tank Size: _____ gallons
Number of trenches: 2
Exact length of each trench: 50 feet
Trench Spacing: 9 Feet on Center
Soil Cover: 12-24 inches
Maximum Trench Depth: 24-36 inches
(Pump Requirements: _____ ft. TDH vs. _____ GPM
Aggregate Depth: 6 inches below pipe, 2 inches above pipe, 12 inches total)

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] RENT Date: 12/5/16
Construction Authorization Expiration Date: 12/8/21


HTE# 15-5-367052

Permit # 29119

Harnett County Department of Public Health Site Sketch

ISSUED TO: WILLIAM JEFFREY BYRD PROPERTY LOCATOR: HOLLIES PINES RD
SUBDIVISION TURKEY TAOT II LOT # 14

Authorized State Agent: ~~REDA~~ (OLIVER TOLKSDORF) Date: 12/6/16



ROAD