

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: 54148 ATKENS RD

SUBDIVISION: ATKENS VILLAGE LOT # 19

ISSUED TO: Royal Oaks Building Group

NEW [] REPAIR [] EXPANSION []

Type of Structure: SFD

Proposed Wastewater System Type: 25% RAINWATER

Projected Daily Flow: 480 GPD

Number of bedrooms: 4 Number of Occupants: 8 max

Basement [] Yes [] No

Pump Required: [] Yes [] No [] May be required based on final location and elevations of facilities

Type of Water Supply: [] Community [] Public [] Well Distance from well _____ feet

Permit valid for: [] Five years [] No expiration

Permit conditions: _____

Authorized State Agent: James E. Markham Date: 10-19-15

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Royal Oaks Building Group

PROPERTY LOCATION: 54148 ATKENS RD

SUBDIVISION: ATKENS VILLAGE LOT # 19

Facility Type: SFD [] New [] Expansion [] Repair

Basement? [] Yes [] No Basement Fixtures? [] Yes [] No

Type of Wastewater System** 25% RAINWATER SYSTEM (Initial) Wastewater Flow: 480 GPD

(See note below, if applicable [])

25% RAINWATER SYSTEM (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons

Pump Tank Size _____ gallons

Number of trenches 3

Exact length of each trench 120 feet

Trenches shall be installed on contour at a

Maximum Trench Depth of: 24 inches

(Trench bottoms shall be level to +/- 1/4"

in all directions)

Trench Spacing: 7 Feet on Center

Soil Cover: 6 inches

(Maximum soil cover shall not exceed

36" above the trench bottom)

Pump Requirements: _____ ft. TDH vs. _____ GPM

Aggregate Depth: 6 inches below pipe

2 inches above pipe

12 inches total

Conditions: _____

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.

NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This

Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Markham Date: 10-19-15

Construction Authorization Expiration Date: 10-19-20

HTE# 15-5-3742

Permit # 28572

Harnett County Department of Public Health Site Sketch

PROPERTY LOCATOR: SW 1448 ATKINS RD

ISSUED TO: Royal OAKS Building Group SUBDIVISION ATKINS VILLAGE LOT # 19

Authorized State Agent: James E. Markant Date: 10-19-15

