

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: Date Evaluated:  
 Address: Design Flow (.1949): 360 gpd Property Size:  
 Proposed Facility: 3 BR/2 BA Property Recorded:  
 Location of Site: Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
LS 2.5		0-30	GS	VFA NS/MP					
		30-46	SBK SCL	FR SS/R	10-27/20-40"				P3 .4
		0-29	GS	VFA NS/MP					
		29-41	SBK SCL	FR SS/S	10-27/20-40"				P3 .21

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)	✓	✓	Site Classification (.1948): P3
System Type(s)	PVMP	25%	Evaluated By: OS
Site LTAR	4	4	Others Present:

4x60 @ 30"-18"