

**COUNTY OF HARNETT**  
**Building Inspections Department**  
**Planning Services**

**Certificate of Compliance:** \_\_\_\_\_ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD  
Name: H&H Onsite Homes LLC

Address: 19 Walnut Grove Dr

Date: 12-28-17

Building Official: James T Hall

**Permit Numbers**  
Building: \_\_\_\_\_  
Electrical: \_\_\_\_\_  
Insulation: \_\_\_\_\_  
Plumbing: \_\_\_\_\_  
Mechanical: \_\_\_\_\_  
MFG Home: \_\_\_\_\_

*15-50037638*

THE UNIVERSITY OF CHICAGO

PHYSICS DEPARTMENT

PHYSICS 311

LECTURE 1

MECHANICS

PROBLEM SET 1

DATE: \_\_\_\_\_

NAME: \_\_\_\_\_

ADDRESS : 19 WALNUT GROVE DR  
CONTRACTOR : H & H ONSITE HOMES LLC  
OWNER : EVEN PAR DEVELOPMENT LLC  
PARCEL : 01-0525- - -0062- -10-  
APPL NUMBER: 15-50037638 CP NEW RESIDENTIAL (SFD)

SUBDIV: WALNUT GROVE 37LOTS  
PHONE : (910) 486-4864  
PHONE :

DIRECTIONS : T/S: 12/03/2015 01:36 PM JBROCK ----  
19 WALNUT GROVE DR LOT 1

**STRUCTURE: 000 000 42.8X61 3BDR CRAWL W/ GARAGE**

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3000000.00  
SEPTIC - EXISTING? : NEW TANK  
PROPOSED USE : SFD  
WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/17/16 8/17/16	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002858579 T/S: 08/16/2016 01:23 PM JFORBES
A814 01	8/30/16 8/26/16	SB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002862506 19 WALNUT GROVE DR BUNNLEVEL 28323 T/S: 08/26/2016 10:34 AM SBENNETT
B101 02	8/30/16 8/30/16	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002864171 T/S: 08/30/2016 08:40 AM JFORBES T/S: 08/30/2016 08:40 AM JFORBES
B103 01	9/07/16 9/07/16	MR AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002867463 T/S: 09/06/2016 02:03 PM JBROCK T/S: 09/07/2016 02:42 PM MREARIC
B111 01	9/13/16 9/13/16	JH CA	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002870392 T/S: 09/12/2016 12:58 PM JBROCK porch & garage inspection PER david
B105 01	9/20/16 9/20/16	JH AP	R*OPEN FLOOR TIME: 17:00 VRU #: 002873305 T/S: 09/19/2016 08:24 AM JBROCK
B111 02	10/07/16 10/07/16	JH DA	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002882371 T/S: 10/06/2016 02:51 PM JBROCK slab inspection on porch Can not use aluminum flashing on concrete
R425 01	11/02/16 11/02/16	MR DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002892396 T/S: 10/31/2016 02:36 PM JBROCK rough-in & porch prep T/S: 11/02/2016 01:47 PM MREARIC install protection on gas line at fireplace.....wire all bath fans .....bedroom door framing is loose .....install baffles ..... ok to side , but NO insulation yet
I129 01	11/04/16 11/04/16	MR DA	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002894418 T/S: 11/03/2016 01:33 PM LBENNETT T/S: 11/04/2016 12:52 PM MREARIC
R425 02	11/04/16 11/04/16	MR AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002894426 T/S: 11/03/2016 01:33 PM LBENNETT T/S: 11/04/2016 12:52 PM MREARIC
I129 02	11/09/16 11/09/16	JH AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002895621 T/S: 11/07/2016 02:15 PM JBROCK

11

ADDRESS . : 19 WALNUT GROVE DR  
CONTRACTOR : H & H ONSITE HOMES LLC  
OWNER . . : EVEN PAR DEVELOPMENT LLC  
PARCEL . . : 01-0525- - -0062- -10-  
APPL NUMBER: 15-50037638 CP NEW RESIDENTIAL (SFD)

SUBDIV: WALNUT GROVE 37LOTS  
PHONE : (910) 486-4864  
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E209 01	2/15/17 2/15/17	JH AP	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002933588 T/S: 02/14/2017 01:08 PM JBROCK
H824 01	3/08/17 3/08/17	OT AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002943322 T/S: 03/09/2017 09:54 AM KHINSON T/S: 03/09/2017 09:55 AM KHINSON
M305 01	3/10/17 3/10/17	JH AP	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 002943645 T/S: 03/09/2017 02:40 PM JBROCK
P307 01	3/10/17 3/10/17	JH DA	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 002943652 T/S: 03/09/2017 02:40 PM JBROCK uncover water line for inspection
P307 02	3/15/17 3/15/17	JH AP	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 002945053 T/S: 03/14/2017 01:20 PM JBROCK
R429 01	12/19/17 12/19/17	JH DA	FOUR TRADE FINAL TIME: 17:00 VRU #: 003068418 T/S: 12/18/2017 11:10 AM JBROCK 1) Energy certificate. 2) Front kick boards of steps in garage. 3) Seal hole in sheetrock behind dishwasher. 4) Missing child safety latches on windows upstairs. 5) Remove access panel in front right bedroom closet for inspection. 6) No water on sinks throughout house. 7) Need to cover untreated wood to side of back porch. 8) Insulation down under house.
R429 02	12/28/17 <u>12-28-17</u>	TI <i>AP JH</i>	FOUR TRADE FINAL TIME: 17:00 VRU #: 003069572 T/S: 12/22/2017 10:27 AM JBROCK

COMMENTS AND NOTES

