

HTE# 15-5-57638

Harnett County Department of Public Health

Improvement Permit

28767

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: H+H Onsite Homes PROPERTY LOCATION: WALNUT GROVE DR
 NEW REPAIR EXPANSION SUBDIVISION WALNUT GROVE LOT # 1
 Type of Structure: SFD (43x61) Site Improvements required prior to Construction Authorization Issuance:
 Proposed Wastewater System Type: 25% REDUCTION SYSTEM INSTALL TEMPORARY FENCE BETWEEN HOUSE
 Projected Daily Flow: 360 GPD SITE AND FIRST DRAIN LINE (PINK/PINK) TO
 Number of bedrooms: 3 Number of Occupants: 6 max PREVENT ANY FUTURE CONSTRUCTION TRAFFIC
 Basement Yes No ON DRAIN FIELD AREA.
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well 100 feet Permit valid for: Five years
 Permit conditions: No expiration

Authorized State Agent: [Signature] Date: 3/1/16 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: _____ PROPERTY LOCATION: _____
SUBDIVISION _____ LOT # _____

Facility Type: _____ New Expansion Repair

Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** _____ (Initial) Wastewater Flow: _____ GPD
(See note below, if applicable)

Installation Requirements/Conditions

Septic Tank Size _____ gallons

Pump Tank Size _____ gallons

Number of trenches _____

Exact length of each trench _____ feet

Trenches shall be installed on contour at a

Maximum Trench Depth of: _____ inches

(Trench bottoms shall be level to +/-1/4"

in all directions)

Trench Spacing: _____ Feet on Center

Soil Cover: _____ inches

(Maximum soil cover shall not exceed

36" above the trench bottom)

Pump Requirements: _____ ft. TDH vs. _____ GPM

Aggregate Depth: _____ inches below pipe

_____ inches above pipe

_____ inches total

Conditions: _____

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: _____ Date: _____

Construction Authorization Expiration Date: _____