

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: 4 BORM Design Flow (.1949): 480 SP
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
		0"	SBK SCL	F1	10YR2/2e 3"				US
		0-11	G LS						
		11-25"	SBK SCL	F1 s/p	10YR2/2e 3"				
		0-23	G LS						
		23-32	SBK SCL	F1 ss) sp					RS .4
		TOO WET EVALUATE DEGREE 2							
		0-20"	G LS						
		20"	SBK SC	F1 ss) sp	10YR2/2e 2"				US

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: Others Present:
Available Space (.1945)			
System Type(s)			
Site LTAR			

COMMENTS: _____

LANDSCAPE POSITIONS

R-RIDGE
 S-SHOULDER SLOPE
 L-LINEAR SLOPE
 FS-FOOT SLOPE
 N-NOSE SLOPE
 H-HEAD SLOPE
 CC-CONCLAVE SLOPE
 CV-CONVEX SLOPE
 T-TERRACE
 FP-FLOOD PLAN

GROUP

TEXTURES

.1955 LTAR

CONSISTENCE MOIST

WET

I

S-SAND
 LS-LOAMY SAND

1.2 - 0.8

VFR-VERY FRIABLE

NS-NON-STICKY

II

SL-SANDY LOAM
 L-LOAM

0.8 - 0.6

FR-FRIABLE

SS-SLIGHTLY STICKY

FI-FIRM

S-STICKY

VFI-VERY FIRM

VS-VERY STICKY

EFI-EXTREMELY FIRM

NP-NON-PLASTIC

III

SI-SILT
 SIL-SILT LOAM
 CL-CLAY LOAM
 SCL-SANDY CLAY LOAM

0.6 - 0.3

SP-SLIGHTLY STICKY

P-PLASTIC

VP-VERY PLASTIC

IV

SIC-SILTY CLAY
 C-CLAY
 SC-SANDY CLAY

0.4 - 0.1

STRUCTURE

SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY

SLIGHTLY EXPANSIVE

EXPANSIVE

Show profile locations and other site features (dimensions, references or benchmark, and North)

A large grid for site profile locations and other site features (dimensions, references or benchmark, and North). The grid consists of 20 columns and 20 rows of squares, providing a space for drawing and recording field data.