HTE# 15-5-3769]

Harnett County Department of Public Health

28751

Improvement Permit

A building permit cannot be issued with only an Improvement Permit
PROPERTY LOCATION: TINGEN RD
ISSUED TO: BILL CLARGE HOMES SUBDIVISION PATIONS POINT LOT # 51
NEW REPAIR REPAIR EXPANSION EXPANSION Site Improvements required prior to Construction Authorization Issuance:
Type of Structure: SFD (55 x 4 5)
Proposed Wastewater System Type: 25% REDUCTION SYSTEM
Projected Daily Flow: 360 GPD
Number of bedrooms: 3 Number of Occupants: 6 max
Basement 🗆 Yes 🗷 No
Pump Required: ☐Yes ☐ No ☐May be required based on final location and elevations of facilities
Type of Water Supply: Community Public Well Distance from well Five years Permit conditions: No expiration
Authorized State Agent:: Date: 2 17 16 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.
Construction Authorization
(Required for Building Permit)
The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance
with the attached system layout.
ISSUED TO: BILL CLARK HOMES PROPERTY LOCATION: TINGEN RD
SUBDIVISION PATIONS POINT LOT # 5)
Facility Type: 580 (55 145) DK New Expansion Repair
Basement? 🗆 Yes 🗵 No Basement Fixtures? 🗆 Yes 🔀 No
Type of Wastewater System** 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 360 GPD
(See note helow if applicable [])
Pume To 25% Repair)
Installation Requirements/Conditions Number of trenches
Septic Tank Size 1000 gallons Exact length of each trench 120 feet Trench Spacing: Feet on Center
Maximum Trench Depth of: 18-36 inches (Maximum soil cover shall not exceed
(Trench bottoms shall be level to $\pm 1/4$ " 36" above the trench bottom)
in all directions)
Pump Requirements:ft. TDH vs GPMinches below pipe
Aggregate Depth: inches above pipe
N P.
onditions: inches total
VATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
IO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.
*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
Owner/Legal Representative Signature: Date:
his Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This
onstruction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.
Authorized State Agent: Date: 2/17/14 Date: 2/17/14
Date.

Harnett County Department of Public Health Site Sketch

