

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: \_\_\_\_\_ Applicant: \_\_\_\_\_  
 Address: \_\_\_\_\_ Date Evaluated: 1/13/16  
 Proposed Facility: \_\_\_\_\_ Design Flow (.1949): \_\_\_\_\_ Property Size: \_\_\_\_\_  
 Location of Site: \_\_\_\_\_ Property Recorded: \_\_\_\_\_  
 Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
	LS99	0-13	G/SL	VFr NSNP					
		13-35	Sbk/C	F:SSC					
		35-42	Sbk/sc1	F:SSSP					PS
		42-60	G/LS	VFr NSNP					
		0-12	G/SL	VFr NSNP					
		12-48	Sbk/sc1	F:SSSP					PS
		48-60	G/LS	VFr NSNP					
		0-8	G/SL	VFr NSNP					
		8-32	Sbk/C	F:SSP					
		32-48	Sbk/sc1	F:SSSP					PS
		48-60	G/LS	VFr NSNP					

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: BU Others Present:
Available Space (.1945)			
System Type(s)	25'	25'	
Site LTAR	.5	.5	