

**COUNTY OF HARNETT
Building Inspections Department
Planning Services**

Certificate of Compliance: _____ **Occupancy:** ✓

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Name: Atlantic Construction

Address: 15 Folly Ct

Date: 6-21-16

Building Official: _____

[Signature]

Permit Numbers

Building: _____

Electrical: 15-50037731

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

ADDRESS : 15 FOLLY CT
CONTRACTOR : ATLANTIC CONSTRUCTION
OWNER : DIVERSIFIELD INVESTORS INC
PARCEL : 01-0544- - -0004- -55-
APPL NUMBER: 15-50037731 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 12/21/2015 07:55 AM DJOHNSON --
SWEETWATER #47
T/S: 12/21/2015 11:52 AM DJOHNSON --

SUBDIV: SWEETWATER 71LOTS
PHONE : (910) 938-9053
PHONE :

STRUCTURE: 000 000 45.2X42 6 3 BR ATT GARAGE, PORCH, FIN BON

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/22/16	JH	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002779304
	2/22/16	AP	T-POLE PASSED LOT 63
A814 01	3/03/16	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002784148
	3/03/16	AP	15 FOLLY CT LINDEN 28356 T/S: 03/03/2016 09:20 AM SBENNETT -----
B103 01	3/03/16	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002784130
	3/03/16	AP	-----
B104 01	3/07/16	JB	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002785673
	3/07/16	AP	T/S: 03/07/2016 08:52 AM JBROCK -----
P309 01	3/09/16	JH	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002785848
	3/09/16	AP	-----
B111 01	3/14/16	JH	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002787893
	3/14/16	AP	-----
R425 01	4/11/16	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002801280
	4/11/16	DA	T/S: 04/08/2016 01:09 PM LBENNETT ----- 1)Missing nut & washer on anchor bolt in gareg on wing wall.2)Replace overnotched studs on end wall & to right of window in living room.3)Missing anchor bolts on each side of front & back door & to right of stove.4)Missing plumbing roof boots.5)Anchor all interior load bearing walls per code.6)Missing baffels in house.7)Furr wall in laundry room.8)Need stud at osb joint under window in front bed closet.9)Nail 2ply trusses per truss documents. OK TO SIDE DDO NOT INSULATE
I129 01	4/14/16	MR	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002802981
	4/14/16	AP	T/S: 04/14/2016 02:26 PM MREARIC -----
R425 02	4/14/16	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002802965
	4/14/16	AP	T/S: 04/14/2016 02:26 PM MREARIC -----
H824 01	4/26/16	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002808772
	4/26/16	AP	T/S: 04/27/2016 11:50 AM SSTEWARD ----- T/S: 04/27/2016 11:50 AM SSTEWARD -----
M305 01	5/03/16	JH	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 002811370
	5/03/16	CA	T/S: 05/02/2016 02:16 PM JBROCK ----- PER JOHN
P307 01	5/03/16	JH	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 002811388
	5/03/16	CA	T/S: 05/02/2016 02:16 PM JBROCK ----- PER JOHN
M305 02	5/11/16	JH	R*PLUMB SEWER CONNECTION TIME: 17:00 VRU #: 002814622

ADDRESS : 15 FOLLY CT
 CONTRACTOR : ATLANTIC CONSTRUCTION
 OWNER : DIVERSIFIELD INVESTORS INC
 PARCEL : 01-0544- - -0004- -55-
 APPL NUMBER: 15-50037731 CP NEW RESIDENTIAL (SFD)

SUBDIV: SWEETWATER 71LOTS
 PHONE : (910) 938-9053
 PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	5/11/16	AP	T/S: 05/10/2016 01:27 PM JBROCK -----
P307 02	5/11/16	JH	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 002814630
	5/11/16	AP	T/S: 05/10/2016 01:27 PM JBROCK -----
E209 01	5/31/16	JH	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002822765
	5/31/16	CA	T/S: 05/26/2016 01:30 PM JBROCK ----- PER JOHN
E209 02	6/01/16	JH	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002823953
	6/01/16	CA	T/S: 05/31/2016 02:09 PM JBROCK ----- PER JOHN
E209 03	6/03/16	JH	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002825594
	6/03/16	CA	T/S: 06/02/2016 02:10 PM DJOHNSON ----- PER JOHN
E209 04	6/09/16	JH	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002827855
	6/09/16	AP	T/S: 06/08/2016 09:23 AM DJOHNSON ----- T/S: 06/08/2016 09:57 AM DJOHNSON ----- *****LOCK BOX CODE 0566*****
R429 01	6/15/16	JH	FOUR TRADE FINAL TIME: 17:00 VRU #: 002830644
	6/15/16	CA	T/S: 06/14/2016 10:54 AM JBROCK ----- PER JOHN
R429 02	6/21/16	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002833861
	<u>6-21-16</u>	<u>AP JH</u>	T/S: 06/20/2016 12:47 PM DJOHNSON -----

----- COMMENTS AND NOTES -----