

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: *North East*
 Address: Date Evaluated: *1-27-2016*
 Proposed Facility: *SFT* Design Flow (.1949): *480* Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

| P R O F I L E # | .1940 Landscape Position/ Slope % | Horizon Depth (In.) | SOIL MORPHOLOGY .1941 | | OTHER PROFILE FACTORS | | | | Profile Class & LTAR |
|--------------------------------------|--|---------------------------|--------------------------------|------------------------------------|------------------------------------|------------------------------|-------------------------|-------------------------|----------------------------|
| | | | .1941 Structure/ Texture | .1941 Consistence Mineralogy | .1942 Soil Wetness/ Color | .1943 Soil Depth (IN.) | .1956 Sapro Class | .1944 Restr Horiz | |
| 1.2 | L-562 | 0-10 | SL-1 | ALL GRASSY | | | | | |
| | | 10-36 | SL-1 clay | FRM 1/2" SP. - P. | 32-34 | | | | .3 |
| 3.5 | L-457 | 0-8 | SL | ALL GRASSY | | | | | |
| | | 8-16 | SC- | FRM 1/2" SP. - P. | 34-36 | | | | .3 |
| 4 | L-590 | 0-12 | SL | ALL GRASSY | | | | | |
| | | 12-42 | SC- | FRM 1/2" SP. - P. | 32-34 | | | | .3 |

| | | | |
|-------------------------|----------------|---------------|---|
| Description | Initial System | Repair System | Other Factors (.1946): Site Classification (.1948): <i>PS</i> Evaluated By: <i>[Signature]</i> Others Present: |
| Available Space (.1945) | | | |
| System Type(s) | <i>25%</i> | <i>25%</i> | |
| Site LTAR | <i>.3</i> | <i>.3</i> | |