

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: *Cubler* 330-3116  
 Address: Date Evaluated:  
 Proposed Facility: *SFD* Design Flow (.1949): *360* Property Size:  
 Location of Site: Property Recorded:  
 Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1,2	<i>C. 5' 60"</i>	0-12	<i>SL</i>	<i>in GWSRP</i>					
		18-42	<i>SC-clay</i>	<i>in GWSRP</i>	<i>34-36' 5M, 3-1</i>				<i>.3</i>
3	<i>2' 40"</i>	0-5	<i>LOA</i>	<i>in GWSRP</i>					
		5-40	<i>SL-clay</i>	<i>in GWSRP</i>	<i>30-32' 5M, 3-1</i>				<i>1.3 -&gt; .25</i>

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <i>PS</i> Evaluated By: <i>JM</i> Others Present:
Available Space (.1945)			
System Type(s)	<i>252</i>	<i>LPD</i>	
Site LTAR	<i>.3</i>	<i>1.3 -&gt; .25</i>	