

HTE# 16-5-38165

Harnett County Department of Public Health

28812

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: 511448 ATKINS RD

ISSUED TO: Royal Oaks Building Group

SUBDIVISION ATKINS VILLAGE LOT # 9

NEW REPAIR EXPANSION

Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: SFD

Proposed Wastewater System Type: 25% REDUCTION

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max

Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities

Type of Water Supply: Community Public Well Distance from well _____ feet

Permit valid for: Five years

Permit conditions: _____

No expiration

Authorized State Agent: James E. Manhart JR. PE

Date: 3-23-16

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Royal Oaks Building Group

PROPERTY LOCATION: 511448 ATKINS RD

SUBDIVISION ATKINS VILLAGE LOT # 9

Facility Type: SFD New Expansion Repair

Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** Pump to 25% REDUCTION (Initial) Wastewater Flow: 360 GPD

(See note below, if applicable)

25% REDUCTION (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons

Number of trenches 3

Exact length of each trench 80 feet

Trench Spacing: 9 Feet on Center

Pump Tank Size 1000 gallons

Trenches shall be installed on contour at a

Soil Cover: 6 inches

Maximum Trench Depth of: 22" inches

(Maximum soil cover shall not exceed

(Trench bottoms shall be level to +/-1/4" in all directions)

36" above the trench bottom)

Pump Requirements: _____ ft. TDH vs. _____ GPM

Aggregate Depth: 6 inches below pipe

2 inches above pipe

Conditions: IF SFD WILL BE ON SLAB and Lot IS CUT

12 inches total

then Permit IS VOID - SLAB NEEDS TO BE BUILT UP.

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.

NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____

Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Manhart JR. PE

Date: 3-23-16

Construction Authorization Expiration Date: 3-23-21

HTE# 16-5-38165

Permit # 28812

Harnett County Department of Public Health Site Sketch

PROPERTY LOCATION: 501448 ATKENS RD

ISSUED TO: Royal Oaks Building Group SUBDIVISION ATKENS VILLAGE LOT # 9

Authorized State Agent: James E. Manhart Date: 3-23-16

- * SFD TO BE WITH CRAWL SPACE - NO SIAB HOME OR GRADING
- * Permit VOID WITH ANY GRADING WORK. ALLOWED.



