

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential
Name: Leicester Patrick M + Wives

Permit Numbers
Building: _____
Electrical: _____
Insulation: _____
Plumbing: _____
Mechanical: _____
MEG Home: _____

Address: 33 Oakridge Dr.

Date: 9/15/17

Building Official: _____

ADDRESS : 33 OAKRIDGE DR SUBDIV: MIRE BRANCH ESTATES
 CONTRACTOR : MOSS KENNETH A PHONE : (910) 893-4875
 OWNER : LANCASTER PATRICK M & NANCY PHONE :
 PARCEL : 09-9566-01- -0001- -73-
 APPL NUMBER: 16-50038230 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : T/S: 03/15/2016 09:37 AM DJOHNSON --
 27 W TOWARDS CAMERON GO PAST 87 THEN
 RIGHT ON MIRE BRANCH INTO MIRE BRANCH
 ESTATES BEFORE THE HWY 24 JUNCTION.
 TURN RIGHT ONCE IN THE DEVELOPMENT ON
 LAKERIDGE. FOLLOW LAKERIDGE TO
 OAKRIDGE TURN LEFT ON OAKRIDGE THE
 PROPERTY IS AT THE END OF OAKRIDGE.


STRUCTURE: 000 000 60X100 4 BR (2) ATT GARAGES, BASEMENT
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/26/17	TSG	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002924546
	1/26/17	AP	T/S: 01/25/2017 01:40 PM JBROCK -----
P309 01	1/26/17	TSG	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002925220
	1/26/17	DA	T/S: 01/26/2017 01:52 PM LBENNETT ----- T/S: 01/26/2017 01:52 PM LBENNETT ----- no test on floor drain T/S: 01/26/2017 02:20 PM SGUY -----
B103 01	1/27/17	TSG	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002925436
	1/27/17	AP	T/S: 01/26/2017 03:11 PM JBROCK -----
P309 02	1/27/17	TSG	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002925428
	1/27/17	AP	T/S: 01/26/2017 03:10 PM JBROCK -----
B111 01	1/30/17	TSG	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002925550
	1/30/17	DA	T/S: 01/27/2017 10:46 AM JBROCK ----- 1- center lug footer required to be dug down to the soil. 2-repair cuts in the plastic barrier near bath area.
A814 01	1/31/17	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002926525
	2/01/17	AP	33 OAKRIDGE DR CAMERON 28326 T/S: 02/01/2017 04:43 PM SBENNETT -----
B111 02	1/31/17	TSG	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002926814
	1/31/17	AP	
B105 01	2/07/17	MR	R*OPEN FLOOR TIME: 17:00 VRU #: 002930105
	2/07/17	AE	T/S: 02/06/2017 01:44 PM JBROCK ----- T/S: 02/07/2017 02:19 PM MREARIC ----- provide plans for rough inspection that show the lvl's
B113 01	2/07/17	MR	R*BLDG WATER/DAMP PROOFING TIME: 17:00 VRU #: 002930113
	2/07/17	AP	T/S: 02/06/2017 01:46 PM JBROCK ----- T/S: 02/07/2017 02:20 PM MREARIC -----
B101 02	3/09/17	TSG	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002942712
	3/09/17	AP	T/S: 03/08/2017 01:14 PM JBROCK ----- garage, porch, & screen porch footing
B103 02	3/24/17	TSG	R*BLDG FOUND & TEMP SVC POLE VRU #: 002948920
	3/24/17	AP	

ADDRESS : 33 OAKRIDGE DR SUBDIV: MIRE BRANCH ESTATES
CONTRACTOR : MOSS KENNETH A PHONE : (910) 893-4875
OWNER : LANCASTER PATRICK M & NANCY PHONE :
PARCEL : 09-9566-01- -0001- -73-
APPL NUMBER: 16-50038230 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B105 02	3/24/17 3/24/17	TSG AP	R*OPEN FLOOR TIME: 17:00 VRU #: 002949097 T/S: 03/23/2017 03:17 PM BPETRICH T/S: 03/23/2017 04:00 PM DJOHNSON
R425 01	5/30/17 5/30/17	TSG DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002977833 T/S: 05/26/2017 01:35 PM JBROCK 1-ANCHOR BOLT REAR GARAGE WALL 2-STRAP GARAGE DOOR LVL 3-FIREBLOCK TOP OF FIREPLACE 4-STRAP STAIR COLOUM 5-ATTACH INTERIOR LOAD BEARING WALLS 6-FIREBLOCK AROUND HVAC UNIT.7-SEAL DAMAGED HOUSE WRAP 8-RE-TEST SHOWER PAN 9-FIREBLOCK TOP OF CHASE IN BASEMENT CORNER 10-FIR CAULK HOLE IN TOP PLATE IN BATHROOM IN BASEMENT.
R425 02	6/02/17 6/02/17	JLP AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002979672 T/S: 06/01/2017 01:47 PM BPETRICH T/S: 06/02/2017 04:04 PM JPERRY
I129 01	6/06/17 6/06/17	TSG AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002980464 T/S: 06/05/2017 10:19 AM JBROCK
H824 01	7/19/17 7/19/17	OT AP	ENVIR. OPERATIONS PERMIT TIME: 08:00 VRU #: 003001591 T/S: 07/21/2017 10:35 AM KHINSON T/S: 07/21/2017 10:35 AM KHINSON
M305 01	9/07/17 9/11/17	TSG AP	R*PLUME SEWER CONNECTION TIME: 17:00 VRU #: 003022399 T/S: 09/07/2017 10:58 AM BPETRICH
P307 01	9/07/17 9/11/17	TSG AP	R*PLUME WATER CONNECTION TIME: 17:00 VRU #: 003022415 T/S: 09/07/2017 10:58 AM BPETRICH
E209 01	9/08/17 9/08/17	TSG AP	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 003022423 T/S: 09/07/2017 10:59 AM BPETRICH
R429 01	9/15/17	TT	FOUR TRADE FINAL TIME: 17:00 VRU #: 003025400 T/S: 09/14/2017 01:11 PM JBROCK



COMMENTS AND NOTES