

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Name: Weaver Development Co INC

Address: 795 River Road

 Fuquay Varina NC 27526

Date: 08/02/2016

Permit Numbers

Building: 16-50038338

Electrical:

Insulation:

Plumbing:

Mechanical:

~~XXXXXX~~ XXXXXX

Building Official: Brad Sutton

ADDRESS : 795 RIVER RD SUBDIV:
 CONTRACTOR : WEAVER DEVELOPMENT CO INC PHONE : (910) 433-0888
 OWNER : MINTON JASON A & MEGAN N PHONE :
 PARCEL : 05-0633- - -0001- -03-
 APPL NUMBER: 16-50038338 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : T/S: 03/29/2016 08:30 AM JBROCK ----
 401 L ON CHRISTIAN LIGHT LIGHT RD L ON
 RIVER RD PASS REGAL CREST AND RAVEN
 RIDGE IS ROAD SIDE LOTS ON THE RIGHT
 SIDE

STRUCTURE: 000 000 56X52 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/19/16	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002804246
	4/19/16	AP	T/S: 04/19/2016 03:26 PM KSLATTUM -----
A814 01	4/25/16	TI	ADDRESS CONFIRMATION VRU #: 002806800
	4/22/16	CA	
B103 01	4/25/16	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 002806792
	4/22/16	CA	
B103 02	4/27/16	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 002808095
	4/27/16	AP	T/S: April 27, 2016 03:16 PM BSUTTON -----
A814 02	4/27/16	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002808087
	4/27/16	AP	795 RIVER RD FUQUAY VARINA 27526 T/S: 04/27/2016 01:50 PM SBENNETT -----
B105 01	5/09/16	BS	R*OPEN FLOOR VRU #: 002813285
	5/09/16	DA	T/S: May 09, 2016 08:42 AM BSUTTON ----- Floor joists on right side of house should be 12" OC per plan
B105 02	5/10/16	BS	R*OPEN FLOOR VRU #: 002813590
	5/10/16	AP	T/S: May 10, 2016 10:54 AM BSUTTON -----
R425 01	5/31/16	BS	FOUR TRADE ROUGH IN VRU #: 002823292
	5/31/16	DA	T/S: May 31, 2016 10:08 AM BSUTTON ----- 1.Change truss hanger nails where 1.5 inch "tico" nails were used. 2. Brace truss M1 and M2 3. No pressure on gas test. OK to side/insulate
I129 01	6/02/16	BS	R*INSULATION INSPECTION VRU #: 002824878
	6/02/16	AP	T/S: June 02, 2016 09:18 AM BSUTTON -----
R425 02	6/02/16	BS	FOUR TRADE ROUGH IN VRU #: 002824886
	6/02/16	AP	T/S: June 02, 2016 09:18 AM BSUTTON -----
E209 01	7/15/16	BS	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002844231
	7/15/16	CA	T/S: 07/14/2016 08:51 AM JBROCK ----- T/S: July 15, 2016 09:06 AM BSUTTON -----
E209 02	7/18/16	BS	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002844868
	7/18/16	AP	T/S: 07/15/2016 11:20 AM DJOHNSON ----- T/S: July 18, 2016 11:24 AM BSUTTON -----
H824 01	7/20/16	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002851079
	7/20/16	AP	T/S: 07/29/2016 04:29 PM SSTEWARD ----- T/S: 07/29/2016 04:29 PM SSTEWARD -----

PREPARED 8/01/16, 14:48:32
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 2
DATE 8/02/16

ADDRESS . . : 795 RIVER RD
CONTRACTOR : WEAVER DEVELOPMENT CO INC
OWNER . . . : MINTON JASON A & MEGAN N
PARCEL . . . : 05-0633- - -0001- -03-
APPL NUMBER: 16-50038338 CP NEW RESIDENTIAL (SFD)

SUBDIV:
PHONE : (910) 433-0888
PHONE :

REQUESTED INSP DESCRIPTION
TYP/SQ COMPLETED RESULT RESULTS/COMMENTS

R429 01 8/02/16 TI FOUR TRADE FINAL TIME: 17:00 VRU #: 002851665
8214 APBS T/S: 08/01/2016 02:48 PM DJOHNSON -----

----- COMMENTS AND NOTES -----