

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: X Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

Name: GML

Address: 19 Heatherwood Dr

Date: 9-26-10

Permit Numbers

Building: 16-50038346

Electrical: _____

Insulation: /

Plumbing: _____

Mechanical: _____

MFG Home: _____

Building Official: T. Michael Reavis

 ADDRESS . : 19 HEATHERWOOD DR SUBDIV: OAKMONT PH 2 SECT 1 30LTS
 TENANT, NBR: CONF#15078
 CONTRACTOR : GML DEVELOPMENT INC PHONE : (919) 793-5237
 OWNER . . : M & JM LLC PHONE :
 PARCEL . . : 03-9589-01- -1021- -04-
 APPL NUMBER: 16-50038346 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/29/2016 03:00 PM JBROCK ----
 OAKMONT #172

STRUCTURE: 000 000 55X31 4BDR MONO W/ GARAGE & PORCH

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	5/24/16	MR	R*PLUMB UNDER SLAB VRU #: 002820587
	5/24/16	AP	T/S: 05/24/2016 01:19 PM MREARIC -----
A814 01	6/01/16	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002823995
	6/01/16	AP	19 HEATHERWOOD DR LILLINGTON 27546 T/S: 06/01/2016 12:43 PM SBENNETT -----
B114 01	6/01/16	MR	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002824019
	6/01/16	AP	T/S: 05/31/2016 02:17 PM JBROCK ----- T/S: 06/01/2016 02:44 PM MREARIC -----
B104 01	6/29/16	JB	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002838431
	6/29/16	AP	T/S: 06/29/2016 04:13 PM JBROCK -----
R425 01	7/13/16	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002843142
	7/13/16	AP	T/S: 07/12/2016 02:31 PM JBROCK ----- T/S: 07/13/2016 02:24 PM MREARIC -----
I129 01	7/18/16	MR	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002845063
	7/18/16	AP	T/S: 07/15/2016 02:12 PM JBROCK ----- T/S: 07/18/2016 03:02 PM MREARIC -----
H824 01	8/01/16	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002852382
	8/01/16	AP	T/S: 08/02/2016 12:48 PM SSTEWARD ----- T/S: 08/02/2016 12:49 PM SSTEWARD -----
E209 01	8/17/16	MR	R*ELEC TEMP POWER CERT VRU #: 002858181
	8/17/16	DA	T/S: 08/17/2016 02:15 PM MREARIC ----- outlet needed at right side of sink
E209 02	8/25/16	MR	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002861672
	8/25/16	DA	T/S: 08/24/2016 09:40 AM JBROCK ----- T/S: 08/25/2016 01:35 PM MREARIC ----- front lights not installed
E209 03	8/29/16	MR	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002863132
	8/29/16	AP	T/S: 08/29/2016 03:14 PM MREARIC -----
R429 01	9/22/16	MR	FOUR TRADE FINAL TIME: 17:00 VRU #: 002875060
	9/22/16	DA	T/S: 09/21/2016 01:31 PM JBROCK ----- T/S: 09/22/2016 01:43 PM MREARIC ----- studor valve too low
R429 02	9/26/16	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002876464
		AP-MR	T/S: 09/23/2016 01:53 PM JBROCK ----- can we meet and discuss exactly what is wrong in house with the inspector - call 910-658-6691

----- COMMENTS AND NOTES -----