

COUNTY OF HARNETT  
Building Inspections Department  
Planning Services

Certificate of Compliance: X Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: B-3

Name: GML

Address: 56 Heatherwood Dr

Date: 9-26-16

Building Official: T. Michael Ream

Permit Numbers

Building: 16-50038349

Electrical: \_\_\_\_\_

Insulation: \_\_\_\_\_

Plumbing: \_\_\_\_\_

Mechanical: \_\_\_\_\_

MFG Home: \_\_\_\_\_

-----  
 ADDRESS : 56 HEATHERWOOD DR SUBDIV: OAKMONT PH 2 SECT 1 30LTS  
 CONTRACTOR : GML DEVELOPMENT INC PHONE : (919) 793-5237  
 OWNER : M & JM LLC PHONE :  
 PARCEL : 03-9589-01- -1021- -28-  
 APPL NUMBER: 16-50038349 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 03/29/2016 03:00 PM JBROCK ----  
 OAKMONT #195  
 -----

**STRUCTURE: 000 000 62.8X46 3BDR MONO W/ GARAGE & PORCH**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY  
 -----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	5/19/16	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002819001
	5/19/16	AP	56 HEATHERWOOD DR LILLINGTON 27546 T/S: 05/19/2016 10:07 AM SBENNETT -----
P309 01	5/19/16	MR	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002819019
	5/19/16	AP	T/S: 05/18/2016 03:09 PM JBROCK ----- T/S: 05/19/2016 02:48 PM MREARIC -----
B114 01	5/27/16	MR	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002822864
	5/27/16	DA	T/S: 05/26/2016 02:13 PM JBROCK ----- T/S: 05/27/2016 01:19 PM MREARIC ----- get a compaction report on disturbed fill at footer
B114 02	6/02/16	MR	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002825024
	6/02/16	AP	T/S: 06/02/2016 02:16 PM MREARIC -----
B104 01	6/29/16	JB	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002838407
	6/29/16	AP	T/S: 06/29/2016 04:11 PM JBROCK -----
R425 01	7/01/16	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002838910
	7/01/16	AP	T/S: 06/30/2016 02:55 PM JBROCK ----- T/S: 07/01/2016 02:20 PM MREARIC -----
I129 01	7/06/16	MR	R*INSULATION INSPECTION VRU #: 002839587
	7/06/16	AP	T/S: 07/06/2016 02:03 PM MREARIC -----
H824 01	8/05/16	OT	ENVR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002854222
	8/05/16	DA	PER OLIVER OPERATIONS PERMIT ON HOLD FOR PUMP TO BE CHECKED. 893-7547 T/S: 08/05/2016 10:53 AM SSTEWARD -----
E209 01	8/09/16	DT	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002855120
	8/09/16	DA	T/S: 08/08/2016 01:54 PM LBENNETT ----- T/S: 08/09/2016 10:52 AM DETAYLOR ----- Install stone, support porch receptacle Connect attic air handler
E209 02	8/12/16	MR	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002856870
	8/12/16	DP	T/S: 08/11/2016 01:34 PM LBENNETT ----- T/S: 08/12/2016 01:35 PM MREARIC ----- front porch outlet is not installed, wires hanging loose
E209 03	8/16/16	MR	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002858066
	8/16/16	AP	T/S: 08/15/2016 04:27 PM JBROCK ----- T/S: 08/16/2016 02:03 PM MREARIC -----
H824 02	8/31/16	OT	ENVR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002866028
	8/31/16	AP	T/S: 09/01/2016 12:34 PM SSTEWARD ----- T/S: 09/01/2016 12:34 PM SSTEWARD -----
R429 01	9/22/16	MR	FOUR TRADE FINAL TIME: 17:00 VRU #: 002875078

Harnett County

INSPECTOR: IVR

DATE 9/26/16

-----  
 ADDRESS . : 56 HEATHERWOOD DR  
 CONTRACTOR : GML DEVELOPMENT INC  
 OWNER . . : M & JM LLC  
 PARCEL . . : 03-9589-01- -1021- -28-  
 APPL NUMBER: 16-50038349 CP NEW RESIDENTIAL (SFD)

SUBDIV: OAKMONT PH 2 SECT 1 30LTS  
 PHONE : (919) 793-5237  
 PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	9/22/16	CA	T/S: 09/21/2016 01:31 PM JBROCK ----- T/S: 09/22/2016 01:44 PM MREARIC ----- studor valve too low
R429 02	9/26/16 <u>11</u>	TI <u>AP-IVR</u>	FOUR TRADE FINAL TIME: 17:00 VRU #: 002876449 T/S: 09/23/2016 01:52 PM JBROCK ----- can we meet and discuss exactly what is wrong in house with the inspector - phone # 910-658-6691

----- COMMENTS AND NOTES -----