

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: \_\_\_\_\_ Applicant: *[Signature]*  
 Address: \_\_\_\_\_ Date Evaluated: *4-17-16*  
 Proposed Facility: *SFA* Design Flow (.1949): *360* Property Size:  
 Location of Site: \_\_\_\_\_ Property Recorded:  
 Water Supply:  Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L	0-5	SL LOM	fr 62.5MP					
		5-36	SC-Cing	fr 1.36S.0	30-32"				-3
2	L	0-8	SL	fr 62.5MP					
		8-10	SC-Cing	fr 1.36S.0	30"				.3
3	L	0-8	SL LOM	fr 62.5MP					
		8-36	SC-Cing		26"				.28

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)			Site Classification (.1948): <i>MS</i>
System Type(s)	<i>21-42</i>	<i>28-LPP</i>	Evaluated By: <i>[Signature]</i>
Site LTAR	<i>-3</i>	<i>.28-.128</i>	Others Present: <i>[Signature]</i>