

HTE# 16-5-38409

Harnett County Department of Public Health

24345

PERMIT # 28842

Operation Permit

New Installation Septic Tank Nitrification Line Repair Expansion

PROPERTY LOCATION: 21426 Cotton RD

Name: (owner) Williant Kelli Edwards SUBDIVISION _____ LOT # 3

System Installer: ADCOCK Excavation Registration # _____

Basement with plumbing: Garage Number of Bedrooms 3

Type of Water Supply: Community Public Well Distance from well _____ feet


System Type: 25% REDUCTION SYSTEM TYPE VI Types V and VI Systems expire in 5 years.

(In accordance with Table V a)

Owner must contact Health Department 6 months prior to expiration for permit renewal.

EZ 44g

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.



PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Rule .1961.
- II. Monitoring: As required by Rule .1961.
- III. Maintenance: As required by Rule .1961. Other: Gentle Valley W
Subsurface system operator required? Yes No
- IV. Operation: _____
- V. Other: _____

D-Box Pump Alarm H2O Line PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: Conventional Other 25% REDUCTION Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface No. of exact length width of depth of
Drainage Field ditches 4 of each ditch 75 feet ditches 3 feet ditches 24 inches

French Drain Required: _____ Linear feet

Authorized State Agent James E. Manhan Date 1-30-17



16-5-38409 (1)



16-5-38409 (2)



16-5-38409 (3)



16-5-38409 (4)



16-5-38409 (5)



16-5-38409 (6)



16-5-38409 (7)



16-5-38409 (8)



16-5-38409 (9)



16-5-38409 (10)



16-5-38409 (11)



16-5-38409 (12)



16-5-38409 (13)



16-5-38409 (14)



16-5-38409 (15)



16-5-38409 (16)



16-5-38409 (17)



16-5-38409 (18)



16-5-38409 (19)



16-5-38409 (20)