



ADDRESS : 115 CHERRY HILL DR SUBDIV: OAKMONT PH1 SC3 52LOTS  
 CONTRACTOR : GML DEVELOPMENT INC PHONE : (919) 793-5237  
 OWNER : OAKMONT DEV PTNRS LLC PHONE :  
 PARCEL : 03-0507-01- -0046- -46-  
 APPL NUMBER: 16-50038420 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 04/07/2016 11:40 AM JBROCK ----  
 OAKMONT #151

**STRUCTURE: 000 000 55.8X65.7 4BDR MONO W/ GARAGE**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 4000000.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	7/11/16	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002841831
	7/11/16	AP	115 CHERRY HILL DR LILLINGTON 27546
			T/S: 07/11/2016 09:28 AM SBENNETT -----
P309 01	7/11/16	MR	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002841849
	7/11/16	AP	T/S: 07/08/2016 02:05 PM JBROCK -----
			T/S: 07/11/2016 01:43 PM MREARIC -----
B114 01	7/18/16	MR	R*BLDG MONO SLAB/TEMP SVC POLE VRU #: 002844934
	7/18/16	AP	T/S: 07/18/2016 03:02 PM MREARIC -----
B104 01	9/06/16	JB	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002867331
	9/06/16	AP	T/S: 09/06/2016 01:13 PM JBROCK -----
R425 01	9/07/16	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002867349
	9/07/16	DA	T/S: 09/06/2016 01:13 PM JBROCK -----
			T/S: 09/07/2016 02:46 PM MREARIC -----
			riser low ---chase needed in back bedroom at 3" pipe --
			foam all air barrier openings
R425 02	9/08/16	TSG	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002868370
	9/08/16	DA	ATTACH B2 4-PLY TRUSS ABOVE GARAGE, PER TRUSS DETAIL
			MARKED.
			OK TO SIDE
R425 03	9/15/16	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002871911
	9/15/16	AP	T/S: 09/14/2016 01:27 PM JBROCK -----
			T/S: 09/15/2016 11:18 AM MREARIC -----
I129 01	9/19/16	MR	R*INSULATION INSPECTION VRU #: 002872935
	9/19/16	DA	T/S: 09/19/2016 02:06 PM MREARIC -----
			2nd floor water lines not insulated in exterior walls
I129 02	9/20/16	MR	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002873768
	9/20/16	AP	T/S: 09/19/2016 04:06 PM LBENNETT -----
			T/S: 09/20/2016 01:37 PM MREARIC -----
E209 01	11/09/16	MR	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002896199
	11/09/16	AP	T/S: 11/08/2016 02:55 PM JBROCK -----
			T/S: 11/09/2016 01:00 PM MREARIC -----
H824 01	11/23/16	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002903284
	11/23/16	AP	T/S: 11/28/2016 09:25 AM KHINSON -----
			T/S: 11/28/2016 09:25 AM KHINSON -----
R429 01	2/01/17	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002927382
			T/S: 01/31/2017 01:32 PM JBROCK -----

COMMENTS AND NOTES

11