

**COUNTY OF HARNETT**  
**Building Inspections Department**  
**Planning Services**

**Certificate of Compliance:** \_\_\_\_\_ **Occupancy:**  X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification:  SFD

Name:  Zachery & Abigail Schachle

Address:  1565 Rodgers Road   
 Fuquay Varina NC 27526

Date:  12/22/2016

**Permit Numbers**

Building:  16-50038433

Electrical: \_\_\_\_\_

Insulation: \_\_\_\_\_

Plumbing: \_\_\_\_\_

Mechanical: \_\_\_\_\_

~~MEG Home~~ \_\_\_\_\_

Building Official:  Brad Sutton

ADDRESS : 1565 ROGERS RD  
 CONTRACTOR : ANGEL STRUCTURES INC  
 OWNER : SCHACHLE ZACHERY & ABIGAIL M  
 PARCEL : 08-0665- - -0001- -03-  
 APPL NUMBER: 16-50038433 CP NEW RESIDENTIAL (SFD)

SUBDIV:  
 PHONE : (919) 612-9547  
 PHONE :

DIRECTIONS : T/S: 04/08/2016 02:04 PM JBROCK ----  
 HWY 401 N TO F-VAR AT INTERSECTION OF  
 401 TO JUDD PKWY TURN R ANGIER RD ABOUT  
 2 MILES AND TURN R ROGERS RD DIRT RD  
 LOT IS ALL THE WAY AT END ON THE LEFT

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/05/16	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002839003
	7/05/16	AP	T/S: July 05, 2016 10:25 AM BSUTTON -----
B103 01	7/08/16	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 002840947
	7/08/16	AP	T/S: July 08, 2016 09:20 AM BSUTTON -----
A814 01	7/12/16	SB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002842359
	7/12/16	AP	1565 ROGERS RD FUQUAY VARINA 27526 T/S: 07/12/2016 11:45 AM SBENNETT -----
R125 01	7/12/16	BS	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 002842367
	7/12/16	AP	T/S: 07/11/2016 12:55 PM LBENNETT ----- WATER PROOFING INSPECTION T/S: July 12, 2016 09:40 AM BSUTTON -----
P309 01	7/25/16	BS	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002848166
	7/25/16	AP	T/S: 07/22/2016 03:47 PM DJOHNSON ----- T/S: July 25, 2016 02:11 PM BSUTTON -----
B111 01	7/29/16	BS	R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 002850463
	7/29/16	AP	T/S: July 29, 2016 11:10 AM BSUTTON -----
R425 01	9/27/16	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002876928
	9/27/16	DA	T/S: 09/26/2016 10:37 AM JFORBES ----- T/S: 09/27/2016 03:41 PM DETAYLOR ----- Steps to upstairs are not to code, cannot be finished space Strap lvls over garage door Install exhaust duct for half bath Okay for brink/insulation
I129 01	9/29/16	BS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002878726
	9/30/16	AP	T/S: 09/28/2016 01:37 PM JFORBES ----- T/S: September 30, 2016 07:59 AM BSUTTON -----
R425 02	9/29/16	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002878734
	9/30/16	AP	T/S: 09/28/2016 01:37 PM JFORBES ----- T/S: September 30, 2016 07:59 AM BSUTTON -----
H824 01	11/02/16	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002895860
	11/02/16	AP	T/S: 11/08/2016 10:14 AM KHINSON ----- T/S: 11/08/2016 10:14 AM KHINSON -----
P307 01	11/22/16	BS	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 002901767
	11/22/16	AP	T/S: 11/21/2016 01:58 PM JBROCK ----- T/S: November 22, 2016 11:18 AM BSUTTON -----
R125 02	11/22/16	BS	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 002901759
	11/22/16	AP	T/S: 11/21/2016 01:58 PM JBROCK ----- lathe inspection T/S: November 22, 2016 11:18 AM BSUTTON -----
H828 01	12/13/16	JM	ENVIRO. WELL PERMIT TIME: 17:00 VRU #: 002910727

ADDRESS . . : 1565 ROGERS RD  
CONTRACTOR : ANGEL STRUCTURES INC  
OWNER . . . : SCHACHLE ZACHERY & ABIGAIL M  
PARCEL . . . : 08-0665- - -0001- -03-  
APPL NUMBER: 16-50038433 CP NEW RESIDENTIAL (SFD)

SUBDIV:  
PHONE : (919) 612-9547  
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	12/13/16	AP	T/S: 12/14/2016 09:52 AM KHINSON ----- T/S: 12/14/2016 09:52 AM KHINSON -----
R429 01	12/20/16 12/20/16	BS DA	FOUR TRADE FINAL TIME: 17:00 VRU #: 002912590 T/S: 12/19/2016 01:48 PM JBROCK ----- T/S: December 20, 2016 02:32 PM BSUTTON ----- Strap top plate in basement at plumbing drop. 2. Kitchen vent must go through roof. 3. Address posted on front. 4. Caulk toilets. 5. Energy certificate
R429 02	12/22/16	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002914364 T/S: December 22, 2016 01:34 PM BSUTTON -----

----- COMMENTS AND NOTES -----