ADDRESS . . : 108 COUNTRYSIDE DR SUBDIV: OAKMONT PH1 SC3 52LOTS
CONTRACTOR : GML DEVELOPMENT INC PHONE : (919) 793-5237
OWNER . . : OAKMONT DEV PTNRS LLC PHONE :
PARCEL . . : 03-0507-01- -0046- -10-
APPL NUMBER: 16-50038661 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : T/S: 05/06/2016 11:14 AM JFORBES ---
108 COUNTRYSIDE DR OAKMONT

STRUCTURE: 000 000 59X51 4BDR MONO W/ GARAGE & DECK
FLOOD ZONE . . . . : FLOOD ZONE X
BEDROOMS . . . . . : 4000000.00 PROPOSED USE . . . . . : SFD
SEPTIC - EXISTING? . . . . : NEW WATER SUPPLY . . . . . : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	7/28/16	TSG	R*PLUMB UNDER SLAB VRU #: 002849966
	7/28/16	AP	
B114 01	8/04/16	MR	R*BLDG MONO SLAB/TEMP SVC POLE VRU #: 002852614
	8/04/16	DA	T/S: 08/04/2016 03:24 PM MREARIC ----------
			need a compaction report
			footers must be 12" into compacted or natural grade
			plan calls for plastic in garage area
B114 02	8/16/16	TI	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002858009
	"	AP-IVR	

---------- COMMENTS AND NOTES ----------

Rec'd tag

SUMMIT
ENGINEERING • LABORATORY • TESTING

FIELD REPORT

PROJECT NAME: Oakmont	PROJECT #: 4240.500
PROJECT LOCATION: Lillington NC	SUMMIT REPRESENTATIVE: J Previtte
DATE: 8-12-16	PRESENT AT SITE:
CLIENT/CONTRACTOR: Mclee homes	TRIPS:
WORK PERFORMED: HA, DCP	TOTAL TIME:

As requested SUMMIT was on site to perform hand auger borings and DCP testing.

Testing indicated that the foundation bearing materials are suitable to support the required 2000 psf capacity at depth and locations tested.

Lot 55
108 Countryside Dr.
Permit # 16-5003866l

SURVEY CONTROL:

RETURN VISIT REQUIRED: YES / NO DATE TIME RETURN:

SIGNED (SUMMIT)

SIGNED (CLIENT/CONTRACTOR IF REQUIRED)