Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant: [illegible]
Address: Date Evaluated: [illegible]
Proposed Facility: SFD Design Flow (.1949): [illegible] Property Size:
Location of Site: Property Recorded:
Water Supply: ☒ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☐ Auger Boring ☒ Pit ☐ Cut
Type of Wastewater: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L-2%	0'-18	SL CLAY	FR GRANULAR					
		18-48	SC CLAY	FR SBKL S.P	3Lo 7.5YR 3.1				.5
2	L 2-3%	0-18	SL	FR GRANULAR					
		18-42	SC CLAY	FR SBKL S.P	40" 7.5YR 3.1				.35
3	L-3-4%	0-24	SL	FR GRANULAR					
		24-42	SC CLAY	FR SBKL S.P.	42" 7.5YR 3.1				.35

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	2 x 4	2 x 4
Site LTAR	.3	.3

Other Factors (.1946):
Site Classification (.1948):
Evaluated By:
Others Present: