

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: SHC Holdings Inc
PROPERTY LOCATION: 321565 SELAS Hayes RD
SUBDIVISION: Hunters Point LOT # 25
NEW [x] REPAIR [] EXPANSION []
Type of Structure: SFD
Proposed Wastewater System Type: 25% RSD/UPP
Projected Daily Flow: 360 GPD
Number of bedrooms: 3 Number of Occupants: 4 max
Basement [] Yes [x] No
Pump Required: [] Yes [] No [x] May be required based on final location and elevations of facilities
Type of Water Supply: [] Community [x] Public [] Well Distance from well _____ feet
Permit conditions: _____ Permit valid for: [x] Five years [] No expiration

Authorized State Agent: [Signature] Date: 6-14-16 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: SHC Holdings Inc
PROPERTY LOCATION: 321565 SELAS Hayes RD
SUBDIVISION: Hunters Point LOT # 25
Facility Type: SFD [x] New [] Expansion [] Repair []
Basement? [] Yes [x] No Basement Fixtures? [] Yes [x] No
Type of Wastewater System: 25% RSD/UPP system (Initial) Wastewater Flow: 360 GPD
(See note below, if applicable [])
Installation Requirements/Conditions
Septic Tank Size 1000 gallons
Pump Tank Size 1006 gallons
Number of trenches 2
Exact length of each trench 120 feet
Trenches shall be installed on contour at a Maximum Trench Depth of: 28-18 inches (Trench bottoms shall be level to +/-1/4" in all directions)
Trench Spacing: 9 Feet on Center
Soil Cover: 4 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
Pump Requirements: _____ ft. TDH vs. _____ GPM
Aggregate Depth: 2 inches below pipe, 2 inches above pipe, 12 inches total
Conditions: _____

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____
This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 6-14-16
Construction Authorization Expiration Date: 6-14-21

HTE# 16-5-38880

Permit # 28882

Harnett County Department of Public Health Site Sketch

ISSUED TO: SHC Holdings INC PROPERTY LOCATOR: 511565 Jettas Hayes RD
SUBDIVISION: Hunters Point LOT # 25

Authorized State Agent: [Signature] Date: 6-14-14

