

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: *3 BDR* Design Flow (.1949): *360 gpd* Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	<i>25 0-2</i>	0-21	<i>G SL</i>	<i>VRN W/HP</i>					
		21-30	<i>SBK S. CL</i>	<i>FR SS/SP</i>					
		30-40	<i>SBK S. L</i>	<i>VRN SS/SP</i>					<i>PS .35</i>
2		0-20	<i>G SL</i>	<i>VRN W/HP</i>					
		20	<i>SBK S. CL</i>	<i>FR SS/SP</i>	<i>10/12 7/22/82</i>				<i>PS .35</i>
3		0-16	<i>G SL</i>	<i>VRN W/HP</i>					
		16-34	<i>SBK S. CL</i>	<i>FR SS/SP</i>					
		34	<i>SBK S. L</i>	<i>VRN SS/SP</i>					<i>PS .35</i>
4		0-22	<i>G SL</i>	<i>VRN W/HP</i>					
		22-36	<i>SBK S. CL</i>	<i>FR SS/SP</i>					
		36	<i>SBK S. L</i>	<i>VRN SS/SP</i>					<i>PS .35</i>

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)	<i>✓</i>	<i>✓</i>	Site Classification (.1948): <i>PS</i>
System Type(s)	<i>2.5"</i>	<i>2.5"</i>	Evaluated By: <i>OK</i>
Site LTAR	<i>.35</i>	<i>.35</i>	Others Present: <i>-</i>