

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: *WV*
 Address: Date Evaluated: *6-26-16*
 Proposed Facility: Design Flow (.1949): *400*
 Location of Site: *5500* Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	<i>L-2-37</i>	<i>0-14</i>							
		<i>14-30</i>				<i>30"</i>		<i>PH</i>	<i>.4</i>
2	<i>L-2-37</i>	<i>0-14</i>			<i>WGNNSD</i>				
		<i>14-31</i>	<i>W 50LSP</i>		<i>W 150USP</i>	<i>31"</i>		<i>R</i>	<i>.4</i>
3	<i>L-2-37</i>	<i>0-18</i>							
		<i>18-37</i>	<i>W 50LSP</i>			<i>37"</i>		<i>PH</i>	<i>.4</i>

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <i>PS</i> Evaluated By: <i>LOT NG</i> Others Present:
Available Space (.1945)			
System Type(s)	<i>20 2 28</i>	<i>28</i>	
Site LTAR	<i>.4</i>	<i>.4</i>	