

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:

Address:

Date Evaluated:

Proposed Facility: 3 hrs em

Design Flow (.1949): 380 gal

Property Size:

Location of Site:

Property Recorded:

Water Supply:

Public Individual Well Spring Other

Evaluation Method: Auger Boring

Pit Cut

Type of Wastewater:

Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	SS 0-2	0-38	GS	VFL NP/EP					
		38-48	SBK SCL	FL SS/MP					PS S
2	LS 5-7	0-15	GS	VFL NP/EP					
		15-28	SBK SCL	FL SS/MP	10YR 7/2 38"				PS S
		28-47							
3		0-30	GS	VFL NP/EP					
		30-40	SBK SCL	FL SS/MP	10YR 7/2 38"				PS S

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Site Classification (.1948):
System Type(s)	25' 10" 6" 0"	PUMP	Evaluated By:
Site LTAR	-5		Others Present:

4x50 @ 24-18"