

July 11, 2016

Weaver Homes, Inc.
350 Wagoner Drive
Fayetteville, NC 28303

**Re: Status of Improvement Permit Applications # 16- 5-39039 & # 16-5-39040
Thomas Manor Lt 21 & Lt 22**

To Whom It May Concern,


An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- _____ 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible *(\$25.00 fee incurred)*
- _____ 2. Use orange flags to mark house corners *(\$25.00 fee incurred)*
- _____ 3. Directions not clear to property *(\$25.00 fee incurred)*
- _____ 4. Property needs only brush or vegetation removed
- _____ 5. Driveway not shown on site plan
- _____ 6. Backhoe pits required
- X_____ 7. Other – Lt 21 - Move house towards lot 20 so side setback is 15 feet.
Lt 22 - Flip house and move towards lot 23 so side setback is 35 feet.**

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Oliver Tolksdorf, R.E.H.S.
Environmental Health OSWW Soil Scientist
Harnett County Department of Public Health

OT/sgs

Copy: Central Permitting