

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: *Wyn*
 Address: Date Evaluated: *7-18-16*
 Proposed Facility: *SFT* Design Flow (.1949): *4 gpd* Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
4.	<i>L-32</i>	<i>0-24</i>	<i>SL</i>	<i>FR GRANULAR</i>					
		<i>24-48</i>	<i>SL</i>	<i>FR BBSK.S.P.</i>	<i>44" Sil 3"</i>				<i>6</i>
2.3	<i>L-T-13</i>	<i>0-14</i>	<i>SL</i>	<i>FR SANDS W/ -SSSP</i>					
		<i>14-40</i>	<i>SC</i>	<i>FR LBSHS P -USUP</i>	<i>30"</i>				<i>3</i>

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <i>PS</i> Evaluated By: <i>[Signature]</i> Others Present: <i>[Signature]</i>
Available Space (.1945)			
System Type(s)	<i>2802</i>	<i>2802.2802</i>	
Site LTAR	<i>3</i>	<i>3</i>	