

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** ✓

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Name: Wynn Construction INC

Address: 114 Mineral Spring Ln

Highway Varina NC 27526

Date: 2.8.17

Building Official:

Brad Gutter

Permit Numbers

Building: 16-50039050

Electrical: " "

Insulation: " "

Plumbing: " "

Mechanical: " "

MFG Home: _____

ADDRESS : 114 MINERAL SPRING LN SUBDIV: AVERY POND 32LOTS
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER : LITTLE CROSS LLC PHONE :
 PARCEL : 08-0653- - -0029- -18-
 APPL NUMBER: 16-50039050 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 06/27/2016 03:46 PM JBROCK ----
 AVERY POND #18

STRUCTURE: 000 000 60X60 4BDR MONO W/GARAGE CBACK PORCH

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	9/02/16	BS	R*PLUMB UNDER SLAB VRU #: 002865821
	9/02/16	AP	T/S: September 02, 2016 10:31 AM BSUTTON -----
B114 01	9/08/16	BS	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002868347
	9/08/16	CA	T/S: 09/07/2016 01:58 PM JBROCK ----- T/S: September 08, 2016 08:56 AM BSUTTON -----
A814 01	9/12/16	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002869493
	9/14/16	AP	114 MINERAL SPRING LN FUQUAY VARINA 27526 T/S: 09/14/2016 03:49 PM TWARD -----
B114 02	9/12/16	BS	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002869501
	9/12/16	AP	T/S: 09/09/2016 11:44 AM DJOHNSON ----- TSP INSPECTION ALSO T/S: September 12, 2016 08:54 AM BSUTTON -----
B104 01	10/13/16	JB	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002884757
	10/13/16	AP	T/S: 10/13/2016 01:10 PM JBROCK -----
R425 01	10/14/16	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002884765
	10/14/16	DA	T/S: 10/13/2016 01:11 PM JBROCK ----- T/S: 10/14/2016 01:32 PM MREARIC ----- need an anchor bolt at latch side of front door fasten interior walls to slab per code bath vent duct at 2nd fl. does not extend outside
I129 01	10/24/16	BS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002888188
	10/24/16	AP	T/S: 10/21/2016 09:01 AM JFORBES ----- T/S: October 24, 2016 01:31 PM BSUTTON -----
R425 02	10/24/16	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002888170
	10/24/16	AP	T/S: 10/21/2016 09:00 AM JFORBES ----- T/S: October 24, 2016 01:31 PM BSUTTON -----
R125 01	11/14/16	BS	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 002897114
	11/14/16	AP	T/S: 11/10/2016 09:17 AM JFORBES ----- stone prep T/S: November 14, 2016 10:25 AM BSUTTON -----
H824 01	11/21/16	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002902237
	11/21/16	AP	T/S: 11/22/2016 10:31 AM KHINSON ----- T/S: 11/22/2016 10:31 AM KHINSON -----
E209 01	12/06/16	BS	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002906873
	12/06/16	AP	T/S: 12/05/2016 01:22 PM JBROCK ----- T/S: December 06, 2016 12:45 PM BSUTTON -----
R429 01	1/30/17	BS	FOUR TRADE FINAL TIME: 17:00 VRU #: 002925626
	1/30/17	DA	T/S: 01/27/2017 11:25 AM JBROCK ----- T/S: January 30, 2017 11:21 AM BSUTTON -----

PREPARED 2/07/17, 14:25:48
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 7
DATE 2/08/17

ADDRESS : 114 MINERAL SPRING LN
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER : LITTLE CROSS LLC
PARCEL : 08-0653- - -0029- -18-
APPL NUMBER: 16-50039050 CP NEW RESIDENTIAL (SFD)

SUBDIV: AVERY POND 32LOTS
PHONE : (919) 528-1347
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R429 02	2/08/17 <i>2-8-17</i>	TI <i>ABS</i>	Need a vent from laundry closet for dryer makeup FOUR TRADE FINAL TIME: 17:00 VRU #: 002930592 T/S: 02/07/2017 01:43 PM JBROCK -----

----- COMMENTS AND NOTES -----