Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: Applicant: Wm
Address: Date Evaluated: 7-18-10
Proposed Facility: Design Flow (.1949): 4BR Property Size:
Location of Site: Property Recorded:
Water Supply: ☑ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☑ Auger Boring ☑ Pit ☐ Cut
Type of Wastewater: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1,2,3	L-	0-14	SL	VFR GR NSW P SSP					
		14-40	SCL	M SBK S.P. USP	30-52"				.3

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)	3-2	3D
Site LTAR	.3	.3

Other Factors (.1946):
Site Classification (.1948):
Evaluated By:
Others Present: