

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: 4 BORN Design Flow (.1949): 480 gpd Property Size:
 Location of Site: Property Recorded: Spring Other
 Water Supply: Public Individual Well
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	<u>LS 5-7</u>	<u>0-20</u>	<u>G SL</u>	<u>VFL NS/NP</u>					
		<u>20-24</u>	<u>SBXSL</u>	<u>FL SS/S</u>					<u>PS .4</u>
2		<u>0-24</u>	<u>G SL</u>	<u>VFL NS/NP</u>					
		<u>20-24</u>	<u>SBXSL</u>	<u>FL SS/S</u>					<u>PS .4</u>
3		<u>0-20</u>	<u>G SL</u>	<u>VFL NS/NP</u>					
		<u>20"</u>	<u>SBXSL</u>	<u>FL SS/S</u>					<u>PS .4</u>

Description	Initial System <input checked="" type="checkbox"/>	Repair System <input type="checkbox"/>	Other Factors (.1946): <u>PS</u> Site Classification (.1948): Evaluated By: <u>OK</u> Others Present: <u>—</u>
Available Space (.1945)			
System Type(s)	<u>AS-90 RSD</u>		
Site LTAR	<u>.4</u>	<u>.4</u>	